



Smart Grid
International
Research
Facility Network

SIRFN Draft Test Protocols for Advanced Battery Energy Storage System Interoperability Functions

ISGAN Technical Paper

Maurizio Verga and Riccardo Lazzari, Ricerca sul Sistema Energetico - RSE S.P.A.
Jay Johnson and David Rosewater, Sandia National Laboratories
Christian Messner, Austrian Institute of Technology
Jun Hashimoto, Fukushima Renewable Energy Institute, AIST

ISGAN Annex 5

About ISGAN Technical Papers

ISGAN technical papers are meant as inputs to the global discourse about smart grid systems. Each reflects the technical work of the author(s) and/or their organization(s) regarding a topic of international interest. ISGAN technical papers address works in progress in the different regions of the world, with the objective to inform further research and analysis for the continued development of smart grid (and broader smart energy) technologies, standards and systems and related enabling policies.

Disclaimer

This publication was prepared for the International Smart Grid Action Network (ISGAN). ISGAN is organized as the Implementing Agreement for a Co-operative Programme on Smart Grids (ISGAN) and operates under a framework created by the International Energy Agency (IEA). The views, findings and opinions expressed herein do not necessarily state or reflect those of any of ISGAN's Participants, any of their sponsoring governments or organizations, the IEA Secretariat, or any of the IEA's member countries. No warranty is expressed or implied, no legal liability or responsibility assumed for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, and no representation made that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring.

Preface

Distributed Energy Resources (DERs) such as energy storage systems (ESS) when deployed at a large scale are capable of significantly influencing bulk and local power systems. While in many cases the negative effects of uncoordinated DER have caused local and system-level challenges, with proper design and control, DER can effectively support the electric grid. DER with advanced control features have been shown to increase hosting capacity by providing voltage support in distribution circuits, supplying ancillary services such as voltage or frequency regulation.

New energy storage targets in Europe and California, energy storage regulations, along with new storage technologies are providing the foundation for massive deployment of energy storage resources. Large-scale storage is common for renewable energy smoothing, peak-shifting, and voltage support, while commercial and residential-scale systems are financially viable in many jurisdictions due to grid codes and other regulations. For instance, electricity prices in Germany are high enough that storing solar energy for use during peak price periods has made home ESS cost effective.

Further, the combination of solar photovoltaics (PV) and energy storage can generate additional value when interoperable grid-support (“advanced grid”) functions allow for intelligent control. In a position paper issued by the European Photovoltaic Industry Association (EPIA), decentralized storage and the ability for those devices to respond to commanded signals will “help support distribution grids operation - and even sometimes avoid costly grid reinforcements.” Widespread adoption of these functions could allow energy storage to remove some of the barriers to high-penetration PV and wind power.

Advanced DER grid functions are not the same across all countries and jurisdictions; and many regions do not have a defined certification procedure to validate the functionality of these devices. As a result, DER system vendors create different versions of their product’s software to be compliant with regional requirements. This adds cost and complexity to the design and certification processes. It also generates disparate testing methods and there is no common set of parameters that can be communicated to the DERs. If a single procedure was created that accounted for all the jurisdictional variations (e.g., a superset of the grid code discrepancies), a single document and procedure could be used to validate all grid code requirements. This is challenging because there are a large number of grid codes and technical rules—each with variations in the function definitions.

The development of an inclusive set of tests for grid support functionality has the potential to open markets for energy storage providers. Data collection redundancies are removed as well, thereby further reducing the overall cost of certification and deployment. Hence, harmonization and standardization of these advanced function tests would bolster the international market for energy storage systems and enable higher penetrations of renewable energy sources.

To accomplish this goal, the proposed “SIRFN BESS” protocol is inclusive of many technical rules and grid codes while being detailed enough for uniform results across laboratories, countries and, even, continents.

Acknowledgments

Under the auspices of the multilateral International Smart Grid Action Network (ISGAN), 17 laboratories in 15 countries across North America, Europe, and Asia collaborate through ISGAN's Annex 5: Smart Grid International Research Facility Network (SIRFN) to support the integration of DERs into the electricity grid with the aim to accelerate the integration of higher penetrations of solar photovoltaics (PV) and other renewable energy resources. ISGAN is an initiative of the Clean Energy Ministerial and a Technology Collaboration Programme operating as part of the International Energy Agency Energy Technology Network (IEA ETN).

RSE research was financed by the Research Fund for the Italian Electrical System under the Contract Agreement between RSE S.p.A. and the Ministry of Economic Development-General Directorate for Nuclear Energy, Renewable Energy and Energy Efficiency in compliance with the Decree of March 8, 2006.

Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE AC04 94AL85000. This work was funded by the U.S. Department of Energy (DOE) Office of Electricity Delivery and Energy Reliability and the DOE Office of International Affairs.

The participation of AIT within ISGAN-SIRFN is funded in the frame of the IEA Research Cooperation program by the Austrian Ministry for Transport, Innovation and Technology under contract no. FFG 839566.

AIST participation was supported by Japan Ministry of Economy, Trade and Industry (METI). The National Institute of Advanced Industrial Science and Technology (AIST) established the Fukushima Renewable Energy Institute (FREIA).

Abstract

In this report, SIRFN laboratories (Sandia, AIT, RSE and FREA) establish a harmonized Battery Energy Storage System (BESS) evaluation/certification protocol for advanced energy storage functions. The authors present this standardized protocol as an adoption or revision option for jurisdictions when creating or modifying certification testing requirements. To complete this process, each laboratory shared information on national, international, and jurisdictional grid codes and standards for BESS. Based on these requirements, and BESS testing and certification literature, a broad list of interoperability functions, use cases, storage capabilities, and requirements were compiled. This list was then consolidated to a unique set of BESS functions for inclusion in the certification procedure. Draft certification protocols for five initial functions were created by the SIRFN group in order to harmonize the international effort to establish a unified set of procedures for interoperability testing of BESS.

Executive Summary

Looking to the future, stakeholders are working on standards to make it possible to manage the potentially complex interactions between DER and the power system. The interconnection of DER to the grid is subject to performance and safety requirements that vary significantly between jurisdictions. Fulfillment of some of these requirements often requires that DER capabilities be certified by an independent testing entity. These codes and certification requirements are in a state of evolution worldwide, and the trend is toward expanding grid support features. To continue, this trend requires greater interoperability between DER and utility energy management systems.

The international standard IEC TR 61850-90-7¹, one example of a DER interoperability standard, was updated in February 2013 to incorporate advanced DER grid support functionality. All countries and jurisdictions do not necessarily conform to IEC TR 61850-90-7; and many regions do not have a defined certification procedure to validate the functionality of DER or energy storage devices. As a result, DER vendors must still create different versions of their software to be compliant with regional requirements. This adds cost and complexity to the design and certification processes. It also generates disparate testing methods as there is no common set of parameters that can be communicated to the DERs. If a single set of parameters was created that accounted for most or all the jurisdictional variations (e.g., a superset of the grid codes), a single procedure could validate all grid code requirements. The development of such a procedure is challenging because there are a large number of grid codes and technical rules—each with variations in the function definitions.

To address this challenge, the Smart-Grid International Research Facility Network (SIRFN) laboratories—Sandia National Laboratories (SNL), Austrian Institute of Technology (AIT), Ricerca sul Sistema Energetico (RSE), and National Institute of Advanced Industrial Science and Technology (AIST) Fukushima Renewable Energy Institute (FREA)—collaborated to create a concise set of test protocols for evaluating the Battery Energy Storage System (BESS)² interoperability and functionality. The approach taken by the SIRFN group was to create a test procedure which covers a superset of grid codes parameters, depicted in Figure 1. If a DER is to be tested to a regional grid code any superfluous parameters can be omitted. Similarly, if a DER is to be tested to many different regional grid codes redundant parameters can be omitted. Both of these cases result in more efficient and less costly certification and hence the potential for a reduction in the overall cost of DER. This report includes interoperability test procedures for BESS beyond the original DER protocols created for IEC 61850-90-7 DER functions in the

¹ IEC Technical Report IEC-61850-90-7 — Communication networks and systems for power utility automation – Part 90-7: Object models for power converters in distributed energy resources (DER) systems Edition 1.0 (Feb 2013).

² Note that this test protocol is primarily designed for inverter-based DERs, so not all ESSs may be tested with this protocol (e.g., pumped hydropower).

Sandia Interoperability Test Protocols.^{3,4} This document will be expanded in the future to include additional functions.




Figure 1. Visualization of integration method for SIRFN BESS protocol.

The development of an inclusive set of tests for grid support functionality has the potential to open markets for energy storage providers. Harmonization and standardization of these advanced function tests would bolster the international market for energy storage systems and enable higher penetrations of renewable power. To accomplish this goal, the proposed SIRFN BESS protocol is inclusive of many technical rules and grid codes while being detailed enough for uniform results across laboratories, countries, and even, continents.

This protocol was developed so the testing parameters and procedures for all functions were effective and portable. To ensure the repeatability and robustness of these protocols, interoperability test beds were constructed at each SIRFN lab to evaluate the effectiveness and portability of the test protocols with different hardware and different grid parameters. Initial experimental results were presented at the 2015 European Photovoltaic Solar Energy Conference⁵.

³ J. Johnson S. Gonzalez, M.E. Ralph, A. Ellis, and R. Broderick, "Test Protocols for Advanced Inverter Interoperability Functions – Main Document," Sandia Technical Report SAND2013- 9880, Nov. 2013.

⁴ J. Johnson S. Gonzalez, M.E. Ralph, A. Ellis, and R. Broderick, "Test Protocols for Advanced Inverter Interoperability Functions – Appendices," Sandia Technical Report SAND2013-9875, Nov. 2013.

⁵ D. Rosewater, J. Johnson, M. Verga, R. Lazzari, C. Messner, R. Bründlinger, K. Johannes, J. Hashimoto, K. Otani, International development of energy storage interoperability test protocols for renewable energy integration, EU PVSEC, Hamburg, Germany, 14-18 Sept, 2015.

Table of Contents

1	Introduction	1
1.1	ESS Grid Codes, Technical Rules, and Standards	3
2	Test Requirements	7
2.1	Test Configuration	7
2.2	Data Acquisition Requirements	9
2.3	Test Procedures	10
3	Preliminary System Characterization Test	12
3.1	DAS, Grid Simulator, and Battery Simulator Accuracies	12
3.2	EUT Capabilities and Operating Limits	12
3.3	Validating Reported EUT Capabilities	14
3.4	ESS Interoperability Characterization	14
4	Request Active Power from Storage Test (INV4)	15
4.1	Function Definition	15
4.2	Parameters	15
4.3	Function Capability Table (FCT)	17
4.4	INV4 Function Test Definitions	17
4.4.1	INV4 Test	17
4.4.2	INV4 Timing Test	17
4.5	INV4 Function Test Sequence	18
4.6	Acceptance Criteria	19
4.6.1	Default Requirements – Generic test Case	19
4.6.2	Italian Technical rule	19
5	Request Reactive Power (VV13)	20
5.1	Function Definition	20
5.2	Parameters	21
5.3	Function Capability Table (FCT)	22
5.4	VV13 Function Test Definitions	22
5.5	VV13 Test	23
5.6	VV13 Timing Test	23
5.7	VV13 Function test Sequence	24
5.8	Acceptance Criteria	25
5.8.1	Default Requirements – Generic test case	25
5.8.2	Italian Technical Rules	25
5.8.3	EN 50438:2013	25
5.8.4	CLC/TS 50549	25
6	Commanded Power Factor Test (INV3)	26
6.1	Function Definition	26
6.2	Parameters	26
6.3	Function Capability Table (FCT)	29
6.4	INV3 Function Test Definition	30
6.4.1	INV3 Test	30
6.4.2	INV3 Timing Test	30
6.5	INV3 Function test Sequence	31
6.6	Acceptance Criteria	32
6.6.1	Default Criteria	32
7	Frequency/Watt “P(f)” Test (FW)	33
7.1	Function Definition	33

7.2	Parameters	35
7.3	Function Capability Table (FCT)	40
7.4	FW Function Test Definition	41
7.4.1	FW Domain Test	41
7.4.2	FW Timing Test.....	44
7.5	FW Function test Sequence.....	45
7.6	Acceptance Criteria	46
7.6.1	Default Requirements.....	47
7.6.2	Italian Technical Rules	47
7.6.3	UL 1741 SA Draft Criteria	47
8	Var-Priority Volt-var "Q(V)" Test (VV12)	49
8.1	Function Definition	49
8.2	Parameters	51
8.3	Function Capability Table (FCT)	54
8.4	VV12 Function Test Definition	55
8.4.1	VV12 Domain Test	55
8.4.2	VV12 Timing Test	57
8.5	VV12 Function test Sequence	58
8.6	Acceptance Criteria	59
8.6.1	Default Criteria.....	59
8.6.2	Italian Technical Rules	59
8.6.3	CLC/TS 50549	60

List of Figures

Figure 1.	Visualization of integration method for SIRFN BESS protocol.	xi
Figure 2.	Laboratory setup for energy storage grid support testing.	7
Figure 3.	Example EUT P-Q operational limits.	13
Figure 4.	Example target PF for an EUT with 'Active Power Priority' enabled.....	29
Figure 5.	Example FW points definition.	38
Figure 6.	Example FW curves.	38
Figure 7.	Example FW response with hysteresis, QuadExit = 1, and TL = 0.	39
Figure 8.	Example FW response with no hysteresis, QuadExit = 1, and TL = 1.....	39
Figure 9.	Time domain FW function – Asymmetric Hysteresis Disabled in under-frequency (left side) and in over-frequency (right side).	40
Figure 10.	Time domain FW function – Asymmetric Hysteresis Enabled in under-frequency (left side) and in over-frequency (right side).	40
Figure 11.	Frequency points required for FW Domain tests.	42
Figure 12.	Frequency vs. time during a portion of the frequency-Watt test.....	47
Figure 13.	Frequency-Watt test criteria.	48
Figure 14.	Frequency-Watt test criteria during return to nominal power with hysteresis enabled.....	48
Figure 15.	Example VV12 points definition.	53

List of Tables

Table 1.	Requirements for Data Acquisition Accuracy	10
Table 2.	Minimum Requirements for Manufacturers Stated Measurement Accuracy.....	12
Table 3.	Review of Grid Codes for the INV4 Function	15
Table 4.	INV4 Parameters	16

Table 5. Manufacturer Parameters	16
Table 6. INV4 Function Capability Table	17
Table 7. INV4 Test Matrix	17
Table 8. INV4 Timing Setting Test Matrix	18
Table 9. Review of Grid Codes for the VV13 Function	20
Table 10. VV13 Parameters	21
Table 11. Manufacturer Parameters	22
Table 12. VV13 Function Capability	22
Table 13. VV13 Test Matrix.....	23
Table 14. VV13 Timing Setting Test Matrix	24
Table 15. Review of Grid Codes for the INV3 Function.....	26
Table 16. INV3 Function Capability	27
Table 17. Manufacturer Parameters	28
Table 18. INV3 Function Capability	30
Table 19. INV3 Test Matrix	30
Table 20. INV3 Timing Setting test Matrix	31
Table 21. Review of Grid Codes for the Freq-Watt Function	34
Table 22. FW Parameters	36
Table 23. Manufacturer Parameters	37
Table 24. Function Capability Table for FW Domain test	41
Table 25. Function Capability Table for FW Timing test.....	41
Table 26. FW Test Curves	43
Table 27. FW Test Matrix	44
Table 28. FW Timing Setting Test Matrix	45
Table 29. Review of Grid Codes for the Volt-var Function	50
Table 30. VV Test Parameters.....	52
Table 31. Manufacturer Parameters	52
Table 32. VV12 Function Capability Table for VV12 Domain Test	54
Table 33. Function Capability Table for VV12 Timing test	54
Table 34. VV12 Test Curves	56
Table 35. VV12 Test Matrix.....	57
Table 36. VV12 Timing Test Matrix.....	58

1 Introduction

Distributed Energy Resources (DERs) such as energy storage systems (ESS) when deployed at a large scale are capable of significantly influencing bulk and local power systems. While in many cases the negative effects of uncoordinated DER have caused local and system-level challenges,^{6,7} with proper design and control⁸, DER can effectively support the electric grid. DER with advanced control features have been shown to increase hosting capacity by providing voltage support in distribution circuits,^{9,10,11} provide ancillary services,^{12,13} and be used for wide-area damping.¹⁴

Advanced DER grid functions are not the same across all countries and jurisdictions; and many regions do not have a defined certification procedure to validate the functionality of these devices. As a result, DER system vendors create different versions of the software to be compliant with regional requirements. This adds cost and complexity to the design and certification processes. It also generates disparate testing methods and there is no common set of parameters that can be communicated to the DERs. If a single procedure was created that accounted for all the jurisdictional variations (e.g., a superset of the grid code discrepancies), a single document and procedure could validate all grid code requirements. This is challenging because there are a large number of grid codes and technical rules—each with variations in the function definitions. For instance, the IEC TR 61850-90-7 defines a ramp time and timeout period for frequency watt (FW), but this is not included in the Italian technical rule (other timing parameters are requested for the re-entry condition). The approach taken by the SIRFN group was to create a test procedure that covers a superset of these parameters, depicted in Figure 1, and therefore includes all timing parameters needed. For example, in the case of testing according to specific requirements, additional and not requested parameters are omitted. Thus, a

⁶ J. von Appen, M. Braun, T. Stetz, K. Diwold, D. Geibel, "Time in the Sun: The Challenge of High PV Penetration in the German Electric Grid," *IEEE Power and Energy Magazine*, vol.11, no.2, pp.55-64, March-April 2013.

⁷ J. C. Boemer, et al "Overview of German Grid Issues and Retrofit of Photovoltaic Power Plants in Germany for the Prevention of Frequency Stability Problems in Abnormal System Conditions of the ENTSO-E Region Continental Europe," 1st international workshop on integration of solar power into power systems, Denmark, October 2011.

⁸ R. Lazzari, et al "Enabling a flexible exchange of energy of a photovoltaic plant with the grid by means of a controlled storage system", *International Journal of Control*, vol. 88, no. 7, pp. 1353-1365, 2015

⁹ J.W. Smith, W. Sunderman, R. Dugan, B. Seal, "Smart inverter volt/var control functions for high penetration of PV on distribution systems," *Power Systems Conference and Exposition (PSCE), 2011 IEEE/PES*, vol., no., pp.1,6, 20-23 March 2011.

¹⁰ J. Seuss, M.J. Reno, R.J. Broderick, R.G. Harley, "Evaluation of reactive power control capabilities of residential PV in an unbalanced distribution feeder," *2014 IEEE 40th Photovoltaic Specialist Conference (PVSC)*, pp. 2094-2099, 8-13 June 2014.

¹¹ C. Winter, R. Schwalbe, M. Heidl, W. Pruggler, "Harnessing PV inverter controls for increased hosting capacities of smart low voltage grids: Recent results from Austrian research and demonstration projects." *4th International Workshop on Integration of Solar Power into Power Systems*, Berlin, Germany, 10-11 Nov, 2014.

¹² A. Oudalov; D. Chartouni, C. Ohler, "Optimizing a Battery Energy Storage System for Primary Frequency Control," *IEEE Transactions on Power Systems*, vol.22, no.3, pp.1259-1266, Aug. 2007.

¹³ A. Hoke, D. Maksimovic, "Active power control of photovoltaic power systems," *2013 1st IEEE Conference on Technologies for Sustainability (SusTech)*, pp.70-77, 1-2 Aug. 2013.

¹⁴ J. Neely, J. Johnson, R. Bryne, R. T. Elliott, "Structured optimization for parameter selection of frequency-watt grid support functions for wide-area damping," *International Journal of Distributed Energy Resources and Smart Grids, DERlab/SIRFN Special Issue on Pre-standardisation Activities in Grid Integration of DER*, 2015

single testing procedure can be used for all the grid codes (and rules) by employing a subset of the test parameters, an abbreviated test procedure, and different pass/fail criteria. Similarly, if the full protocol is used a signal device may be tested for compliance to all of the jurisdictions surveyed.¹⁵

The development of an inclusive set of tests for grid support functionality has the potential to open markets for energy storage providers. Data collection redundancies are removed as well, thereby further reducing the overall cost of certification and deployment. Hence, harmonization and standardization of these advanced function tests would bolster the international market for energy storage systems and enable higher penetrations of solar. To accomplish this, the SIRFN BESS protocol is inclusive of many technical rules and grid codes while being detailed enough for uniform results across laboratories, countries, and even, continents.

The development of the SIRFN BESS Protocol was the result of the following iterative process:

1. Review of appropriate grid codes, technical rules, standards, and BESS functions,
2. Consolidation of function requirements into draft protocol language,
3. Execution of draft protocol to BESS with equipment units at SIRFN laboratories, and
4. Updating draft protocols to improve usability and to generate better results.

In this process, the first step was to survey national and international grid codes and rules to understand the range of capabilities that would need to be tested in order to cover the superset of requirements. The broad survey enabled the identification of any differences in requirements for the functions themselves. Once the differences in requirements were identified, draft protocol language was developed to evaluate the equipment under test (EUT). Generally, two different sets of tests were created for each function: an operational domain test to evaluate the accuracy of the function to reach and maintain the appropriate set-point and the time domain test to measure the BESS time response.

The SIRFN energy storage group has developed five test protocols for the evaluation by the larger group of SIRFN laboratories. Additional protocols will be added in the future and these draft protocols will be updated on an as-needed basis. The rest of this document is organized as follows. Section 1.1 covers the grid codes, technical rules, and standards reviewed in the development process for this report. Section 2 covers the general requirements for BESS laboratory testing and analysis. Section 3 covers preliminary test procedures to prepare for function testing. Sections 4 – 8 cover procedures for testing specific functions as specified by this protocol (Request Active Power from Storage, Request Reactive Power from Storage, Commanded Power Factor, Frequency-Watt, and Volt-var).

¹⁵ It is important to note that this protocol need not include every test point required by every grid code and technical rule to provide an inclusive set of functional tests. Each code first defines the function and its requirements and then develops a test protocol to verify that a device meets these requirements. Instead of running every test defined in every code, this protocol surveys function requirements and then develops its own test protocol to verify functionality.

1.1 ESS Grid Codes, Technical Rules, and Standards

This protocol seeks to harmonize the certification procedures of a wide range of national and international grid codes, technical rules, and certification standards. In order to do this, a superset of requirements are included in the test procedures so that only the applicable experiments need to be performed, but all the tests are defined. For this reason, the same methodology is used for the experiments, including function descriptions, test sequences, and test points. The validation criteria is different for each requirement however, so the grid codes, technical rules, and standards must be consulted for the precise pass/fail criteria if they are not included in this report.

To create the functions, each interconnection code and technical rule was analyzed for similarities and differences in data requirements, specified curve shapes and default values. The following grid requirements and codes are applicable in different regions, though most of them were originally developed for generating systems and only a subset of these include specific function for BESS.

1. Italy
 - A. CEI 0-21¹⁶
 - B. CEI 0-16¹⁷

¹⁶ CEI Reference Technical Rules for the Connection of Active and Passive Users to the LV Electrical Utilities, CEI Reference 0-21-V1, December 2014.

¹⁷ CEI Reference Technical Rules for the Connection of Active and Passive Consumers to the HV and MV Electrical Networks of Distribution Company, CEI 0-16-V1, December 2014.

2. USA

- C. UL 1741 Supplement A¹⁸
- D. IEEE Standard 1547-2003¹⁹
- E. IEEE Standard 1547.1-2005²⁰
- F. IEEE Standard 1547a-2014²¹
- G. California Electric Rule 21²²
- H. Hawaii Rule 14H²³

3. Germany

- I. VDE-AR-N 4105²⁴
- J. VDE TAB 2007²⁵
- K. FGW – TR3²⁶
- L. FNN-Reference²⁷
- M. BDEW MV Technical Guideline²⁸

4. Austria

- N. TOR D4:2013²⁹
- O. ÖVE/ÖNORM EN-50438:2014-07³⁰

¹⁸ Underwriters Laboratories 1741 Supplement A, "Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources," (draft) Feb 2015.

¹⁹ IEEE Standard 1547-2003, Standard for Interconnecting Distributed Resources with Electric Power Systems, 2003.

²⁰ IEEE Standard 1547.1-2005, Standard for Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems, 2005.

²¹ IEEE Standard 1547a-2014, Standard for Interconnecting Distributed Resources with Electric Power Systems: Amendment 1, 2014.

²² Pacific Gas and Electric Company, Electric Rule No. 21, Generating Facility Interconnections, Filed with the CPUC on 20 Jan, 2015.

²³ Hawaiian Public Utilities Commission Tariff Rule 14H, "Interconnection Of Distributed Generating Facilities Operating In Parallel with the Companies' Electric System" Filed 31 Mar 2015.

²⁴ VDE-AR-N 4105:2011-08 "Power generation systems connected to the low-voltage distribution network, Technical requirements for the connection to and parallel operation with low-voltage distribution networks."

²⁵ VDE-Reference TAB 2007, Technical conditions for connection to the low voltage network, 2007.

²⁶ Fördergesellschaft Windenergie und andere Erneuerbare Energien FGW e. V. TR3 "Bestimmung der Elektrischen Eigenschaften von Erzeugungseinheiten am Mittel-, Hoch- und Höchstspannungsnetz," (current status: Revision 23, 01/05/2013).

²⁷ FNN-Reference "Connecting and operating storage units in low voltage networks" Jun. 2013.

²⁸ BDEW MV Technical Guideline: "Generating plants connected to the medium-voltage network - Guideline for generating plants connection to and parallel operation with the medium-voltage network."

²⁹ TOR D4:2013 "Technical and organizational rules for network operators and users, Part D: Special technical rules, Parallel operation of generation facilities with distribution networks."

³⁰ ÖVE/ÖNORM EN 50438:2014-07-01 "Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks"(national version of EN 50438:2013).

5. Japan

- P. METI Guideline³¹
- Q. JEAC 9701-2012³²
- R. JEAC 9701 revision 2013 No. 1³³
- S. JEAC 9701 revision 2015 No. 1³⁴

6. Spain

- T. P.O. 12.3:2006³⁵
- U. P.O. 12.2:2005³⁶
- V. Royal Decree 1565/2010³⁷
- W. Royal Decree 1699/2011³⁸
- X. UNE 206007-1 IN³⁹

7. France

- a. ERDF-NOI-RES 13E⁴⁰

³¹ Agency for Natural Resources and Energy, Ministry of Economy, Trade and Industry (METI), Guideline of grid-interconnection technical requirement for power quality securement, 5 May, 2013.

³² Grid-interconnection Code, JEAC 9701, The Japan Electric Association, 2012.

³³ Grid-interconnection Code, JEAC 9701, revision 2013 No.1, The Japan Electric Association, 2013.

³⁴ Grid-interconnection Code, JEAC 9701, revision 2015 No.1, The Japan Electric Association, 2015.

³⁵ Procedimientos de operación (P.O.) 12.3:2006 “Requisitos de respuesta frente a huecos de tensión de las instalaciones eólicas” (Procedure for verification validation and certification of the requirements of the PO 12.3 on the response of wind farms and photovoltaic plants in the event of voltage dips).

³⁶ Procedimientos de operación (P.O.) 12.2:2005 “Instalaciones conectadas a la red de transporte: requisitos mínimos de diseño, equipamiento, funcionamiento y seguridad y puesta en servicio” (Installations connected to the transport network: minimum requirements for design, equipment, operation and safety and commissioning).

³⁷ Royal Decree 1565/2010, of 19 November, by which regulates and modifies certain aspects relating to the activity of production of electrical energy in special regime.

³⁸ Royal Decree 1699/2011, of November 18, by which the connection is regulated a network of facilities for production of electricity from small power.

³⁹ UNE 206007-1 IN “Requisitos de conexión a la red eléctrica. Parte1: Inversores para conexión a la red de distribución” (Requirements for connection to the mains. Part 1: Inverters for connection to the grid.)

⁴⁰ ERDF-NOI-RES_13E v5 “Protections des installations de production raccordées au réseau public de distribution” (Protections for production facilities connected to the public distribution network).

8. International protocols

- b. EN 50438:2013⁴¹
- c. CLC/TS 50549-1:2015-01 ⁴²
- d. CLC/TS 50549-2:2015-01⁴³
- e. IEC 61850-90-7 and the Sandia Test Protocols for IEC 61850-90-7
- f. RfG:2013⁴⁴

Note that the surveyed codes apply at a variety of locations in the power system (e.g. medium voltage), and to a variety of devices (e.g. grid-connected inverters >6 kW), so not all requirements are applicable to each device under test.

⁴¹ EN 50438:2013 “Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks”

⁴² CLC/TS 50549-1:2015-01 “Requirements for the connection of a generating plant to a distribution system - Part 1: Connection to a LV distribution system and above 16A”

⁴³ CLC/TS 50549-2:2015-01 “Requirements for the connection of a generating plant to a distribution system - Part 2: Connection to a MV distribution system”

⁴⁴ European Network Code Requirements for Generators (RfG):2013 “ENTSO-E Network Code for Requirements for Grid Connection Applicable to all Generators”

2 Test Requirements

The following interoperability tests have a number of requirements for the experimental test configuration, data acquisition system, and communications.

2.1 Test Configuration

This section provides general guidelines of the test setup and test equipment requirements to verify BESS functional interoperability. The specific testing requirements may vary widely depending on the purpose of the test (i.e., which set of advanced functions are being tested). The minimum test setup requirements to perform the experiments are shown below in Figure 2. The Equipment Under Test (EUT), also referred to at the Device Under Test (DUT) is connected to a storage element that is either a battery or a battery simulator and a grid simulator.




Figure 2. Laboratory setup for energy storage grid support testing.

A typical laboratory setup for the Equipment Under Test (EUT) should include the following:

- A **Utility Grid Simulator or grid connection**, which provides a power source or a sink to the DER. In some experiments it is possible to use the utility grid as long as the voltage and frequency are within the test tolerances. However, precise grid voltage and frequency changes are necessary for many of the functions. Therefore, a grid simulator will usually be more appropriate for the test setup than a connection to the actual grid. Note an optional RLC Load Bank may be used with the Utility Grid Simulator if it does not have regenerative (bidirectional real power) capabilities.

- A **Utility Management System Simulator**, which provides, using the proper communication protocols, utility-generated signals, information, commands and requests. The Utility Management System Simulator will be used to send commands to the EUT, as well as to change the parameters that govern the actions and responses of the EUT. The commands will be typically formatted according to IEC TR 61850-90-7 and implemented in a suitable communications protocol, unless otherwise required for the experiment. The Utility Management System Simulator will be configured to send commands formatted to IEC TR 61850-90-7, using a suitable communications protocol (such as Modbus or IEEE 2030.5 “SEP 2.0”). Since some inverters may not be compatible with the communications protocol used by the Utility Management System Simulator, a protocol translator may be required to convert commands. An Energy Management System, meter or other translator may be used to interface the Utility Management System Simulator with the DER inverter.
- The **Equipment Under Test (EUT)**, which includes, at minimum, the inverter and controls. Since some EUTs may include an integrated energy storage element or other energy sources, the boundary of the EUT can be defined in a variety of ways including:
 - BESS inverter
 - BESS inverter + battery
 - Multimode inverter with PV + battery
 - Multimode inverter with PV
 - Multimode inverter with wind turbine + battery
 - Multimode inverter with wind turbine

Testing will call for positive and negative real power flows so it is desired to use a battery simulator when possible to ensure that battery state-of-charge limits do not disrupt the experiments. The EUT is shown as separate from the battery in Figure 2 to identify the necessary data collection points. The EUT may or may not include a battery as integrated equipment. BESS often provide backup power to critical loads in addition to the services they supply to the grid. A critical load bus, as well as sensors for non-critical local loads, may also be included within the boundaries of the EUT.

- **Optional Sources for Local Inputs to the DER**, which could include a meter, an EMS, or other controls or sensors. Inputs such as temperature and time could be provided by the Utility Management Simulator, the Utility Grid Simulator, and/or local sensors or signal generators connected directly to inputs of the EUT. The EUT is required to have communication capabilities for all the interoperability tests described in this document.

Note that the EUT can be connected to either a stable utility grid or to a Utility Grid Simulator that allows the real and reactive power outputs of the DER to be controlled in response to grid voltage and frequency variations, local loads’ or resources’ energy inputs or outputs (real and reactive), and local voltage levels, depending on the test requirements. Power levels identified in this test protocol may need to be reduced due to power limitations of the utility grid, simulators, PV, and/or storage.

2.2 Data Acquisition Requirements

For each test, the following will be logged:

- Interoperability (Communication) Data
 - message sent
 - response received
 - status reports generated and transmitted by the DER
 - commands received (and responses) logged
- Electrical Response (Behavior)
 - time-synchronized data of relevant electrical behavior
- Temporal Information
 - Time the command is sent
 - Time the response is received
 - Time of any alarms

The status reporting and data logging will be completed with the Utility Management System Simulator. However, it might be desirable to use a faster sampling rate than possible through utility-issued commands; that will be accomplished by directly monitoring the outputs of the EUT with appropriate instrumentation and data loggers.

EUT input and output voltages, currents, reactive power, apparent power, and active power will be measured to observe the action taken in response to the commands. Sufficient electrical measurements should be taken to fully characterize the electrical response or behavior of the EUT at the electrical connection point (ECP)—as opposed to the point of common coupling (PCC) because local loads may influence the measurements at the PCC. The sampling rate and test duration should be adequate according to the nature of the electrical behavior being evaluated. Points to be measured include:

- AC voltage at the point of connection
- AC current out of the EUT
- Frequency at the point of connection
- Active and Reactive power at the point of connection
- DC voltage of the energy storage device
- Current in to and out of the energy storage
- DC voltage of the BESS or BESS simulator
- DC current out of the BESS array or BESS simulator.

Required sampling rates and data accuracies are defined by the technical grid interconnection rule/ code/standard that is being tested, via IEC 61557-12 or IEC 61000-4-30, or—if not specified—Table 1 shows maximum acceptable data acquisition measurement tolerances to be used.

Table 1. Requirements for Data Acquisition Accuracy

Parameter	Units	Accuracy Class⁴⁵
Voltage (dc)	Volts	0.2
Voltage (ac)	Volts rms	0.2
Current (dc)	Amps	0.5
Current (ac)	Amps rms	0.5
Active Power	Watts	1
Reactive Power	VA _r	2
Apparent Power	VA	1
Power Factor	Displacement Power Factor	0.2
Frequency	Hz	0.05
Time	Seconds	+/- 10 ms

Test sequences may be repeated as needed to verify response to external variables (temperature effects, power disturbances, etc.). During test, temperature must be controlled in the range 25°C ± 3°C. Additionally, some commands such as power level are not binary; therefore, it may be appropriate to verify interoperability and performance at several power levels.

2.3 Test Procedures

For each functions the procedure will be characterized by:

- Function definition
- Parameters
- Function Capability Table
- Function Test Definition
- Function Test Sequence
- Acceptance Criteria.

Most of the defined advanced functions have optional parameters, tables, or definitions. Some manufacturers may choose to implement the functions in a particular way, or not to implement

⁴⁵ Accuracy Class defined according to IEC 61557-12; class 0.2 means 0.2% of Full Scale range.

some of the functions at all. The test procedures are designed to take into account equipment limitations, such as different equipment ratings and avoiding conflict with voltage and frequency protection. The EUT's source(s) of input signals or locally sensed conditions should be enumerated to ensure the test engineer can account for these considerations. Furthermore, based on the jurisdictional requirements (sometimes referred to as the "source requirements document"), the number of tests and test points may be reduced as these procedures are designed to represent a superset of all requirements.

The test engineer should have knowledge of which of the possible options or capabilities for the functions are implemented in their EUT. A list of tables, modes, default parameters, curves, schedules, control logic, and permissible ranges of parameters should also be provided by the inverter manufacturer. The hierarchy among command functions and the conditions for switching from one mode to another should also be provided. If the EUT technical specifications are insufficient to setup the interoperability test, the manufacturer should be consulted. These capabilities and options are recorded in a Function Capabilities Table (FCT) in order to define the specific tests, and the parameters of those tests, to be conducted.

For each function being tested, the general test procedure is as follows:

- Review manufacturer specifications related to the implementation of standard functions and review communications interface requirements. Prepare a FCT and tailor the test setup and the test sequence accordingly.
- EUT is connected to the sources and sinks under normal operating conditions and for a period of 5 minutes. This is in order to verify that the EUT is operational and stable.
- Verification of communications compatibility. This can be done by issuing a status request to the EUT.
- Test communications functionality. This is performed by issuing a command to the EUT. The purpose is to establish how the EUT implements the function command.
- Test the electrical behavior to determine if the DER successfully executed the communicated command.
- Analysis of the test results.

3 Preliminary System Characterization Test

In order to quantify the performance of equipment used in the experiments, the data acquisition system, grid simulator, and, if applicable, the DC Battery simulator accuracies must be determined.

3.1 DAS, Grid Simulator, and Battery Simulator Accuracies

The accuracies of the data acquisition system shall be determined using calibration techniques from IEEE, IEC, or equivalent standards. Once the Data Acquisition System (DAS) has been calibrated, the accuracies of the grid simulator voltage and frequency are determined. The battery simulator current and voltage behavior will also be quantified.

3.2 EUT Capabilities and Operating Limits

The EUT manufacturers are responsible for reporting the accuracies of their devices. Unless otherwise specified, Table 2 should be used for the minimum required EUT measurement accuracy.

Table 2. Minimum Requirements for Manufacturers Stated Measurement Accuracy⁴⁶

	Minimum Measurement Accuracy	Sensing Speed	Range
Voltage	$\pm 2\% V_{nom}$	10 cycles	85% to 110%
Current	$\pm 2\% I_{max}$	10 cycles	0% to 110%
Frequency⁴⁷	$\pm 0.02\%$	10 cycles	94% to 104%
Active Power	$\pm 5\% P_{rated}$	10 cycles	$20\% < P < 100\%$
Reactive Power	$\pm 5\% Q_{rated}$	10 cycles	$20\% < Q < 100\%$
Power Factor	$\pm 5\% PF_{rated}$	10 cycles	$P > 50\%$

If the manufacturer does not report (or know) the limits of the EUT, it may be necessary to determine the limits of the equipment. Standard reporting values are provided in each of the functions below but often cover the EUT limits, such as:

1. AC operational voltage range of the EUT and/or the programmed L/H VRT curves.
2. AC operational frequency range of the EUT and/or the programmed L/H FRT curves.
3. DC operational voltage range of the EUT
4. DC maximum current
5. Chemistry designation of batteries (e.g. Lithium-Iron-Phosphate)

⁴⁶ Adopted from draft UL 1741 SA, Feb 2016.

⁴⁷ CLC/TS 50549 requires $\pm 0.02\%$ frequency accuracy for measurements between 94% and 104% of nominal.

6. Battery maximum energy capacity (e.g. at maximum open-circuit voltage)
7. Battery nominal energy
8. Active power limits of the EUT
9. Reactive power limits of the EUT
10. Power factor (displacement, $\cos\phi$) limits of the EUT
11. The P-Q operational limits of the EUT. This region is often (semi)circular, but could be elliptical for certain EUTs (see example in Figure 3)
12. Range of SOC limits the EUT can perform each of the grid-support functions.




Figure 3. Example EUT P-Q operational limits.

In certain testing situations, the test engineer may perform preliminary experiments to validate the manufacturer's stated capabilities in order to verify the experiments will run without unexpected outcomes, e.g., high/low voltage tripping.

One common challenge in testing BESS power electronics components is the reliance on the battery to provide the full range of capacities of the EUT. For instance, at high and low states-of-charge, the active power limits of the EUT become restricted and therefore the manufacturer-stated limits of the EUT are not valid in those cases. For this reason, it is advisable to use battery simulators. Without the simulator, reliance on the battery capacities are necessary, which can be effected by SOC, temperature, chemistry, etc. To avoid problems, artificially limiting the operation of the EUT, the experiments should be conducted near the 50% of SOC of the battery, at room temperature, using a battery chemistry which the EUT has been designed.

Further, if certain battery parameters (SOC) are known to change the settings listed above, the manufacturer should provide these limits/capabilities as functions of the battery parameter. If this effect is unknown, although it is time-intensive, the test engineer may determine these limits experimentally prior to running the grid-support functions listed in the sections below.

3.3 Validating Reported EUT Capabilities

Each of the functions in this report are designed to validate the capabilities of the EUTs. In some cases, if the EUT is not performing according to the manufacturer-states limits/capabilities, additional experiments may be necessary to understand the limitations of the EUT to provide feedback to the manufacturer. The design and execution of these additional experiments are left to the test engineer to design and execute.

3.4 ESS Interoperability Characterization

Prior to executing the interoperability grid-support experiments the communications capabilities of the EUT must be validated and all the parameters to be tested demonstrate the read/write permissions with the Utility Management System Simulator. This can be performed also by a 3rd party⁴⁸ or another test fixture.

⁴⁸ The SunSpec Alliance is capable of validating the communication capabilities of SunSpec-compliant EUTs using a testing tool.

4 Request Active Power from Storage Test (INV4)

4.1 Function Definition

This function requests the energy storage system to either charge or discharge as a percentage of the storage system’s charge and discharge capacity. A battery simulator may be used in the test to reduce the time needed for the test by reducing charge and/or discharge times. It should be noted that charge/discharge requests are always subject to the state of charge, temperature, ramp rate limits, and other constraints imposed by the battery. Therefore, the INV4 function should be executed only to the extent that the request is feasible.

This test procedure evaluates the test required in:

- CEI 0-21
- CEI 0-16
- IEC 61850-90-7.

The differences in the grid codes for each of the INV4 functions is provided in Table 3.

Table 3. Review of Grid Codes for the INV4 Function

Country/ Grid Code	Data Requirements	Test Points	Time parameters
Italy/CEI 0-21: 2014-12 (LV) and Italy/CEI 0-16: 2014-12(MV)	P, Q, P_{dc} , $\cos\phi$ measured (sample time 1s, data averaged at 1 min)	Active power from W_{MAXch} to W_{MAXdch} every 20% (11 test points)	Time Delay, Ramp Rate fixed to 20% W_{MAXch}/min and 20% W_{MAXdch}/min
International / IEC 61850-90-7⁴⁹	P measured (1 s average), communications recorded	Active power at W_{MAXch} , $W_{MAXch}/2$, $W_{MAXch}/4$, W_{MAXdch} , $W_{MAXdch}/2$, $W_{MAXdch}/4$	Ramp Rate, Time Delay, Timeout

4.2 Parameters

Before starting the INV4 test, the following parameters will be determined by the manufacturer and test engineer for use in the procedure.

⁴⁹ Evaluated with the Sandia Interoperability Test Protocols

Table 4. INV4 Parameters

Parameter	Notes
P_{BESS}	Requested real power output of the BESS device, expressed as a percentage of the BESS output power capacity (W_{MAXdch}). If negative, this represents real power absorbed by the BESS device, expressed as a percentage of the BESS charge power capacity (W_{MAXch}).
tw	Time window is an optional parameter in which the function is enabled after a delay. The delay can be random or fixed. If the time delay is zero, the command will execute immediately.
r_R	Requested ramp rate ($\%P_{rated}/s$) is an optional parameter defining the slope the EUT must move from the current set point to the new set point. The corresponding requested ramp time $t_R=1/r_R$ expresses the time for a change of $100\%P_{rated}$.
t_{out}	Timeout period is an optional parameter that defines the time after which the EUT will reset the INV4 function and set the active power to a default value. The default timeout period is indefinite (timeout period = 0 – Not Enable).
ChgGrid	Boolean that defines whether the storage system can be charged from the grid.

Table 5. Manufacturer Parameters

Parameter	Notes
W_{MAXch}	Maximum charge active power rating (W), negative value
W_{MAXdch}	Maximum discharge active power rating (W), positive value ⁵⁰
Q_{MAXover}	Maximum over excited reactive power rating (var), positive value ⁵¹
Q_{MAXunder}	Maximum under excited reactive power rating (var), negative value
MSA_w ⁵²	Output Power accuracy (W or %W)
MSA_t	Accuracy of response time (s)
SOC_{opMAX}	Maximum operative state of charge at maximum charge power (%) ⁵³
SOC_{opMIN}	Minimum operative state of charge at maximum discharge power (%)
[tw_{min}, tw_{max}]	Adjustment range of time window (s). t_{w_min} will be 0 for most EUTs
[r_{Rmin}, r_{Rmax}]	Adjustment range of the ramp rate ($\%P_{rated}/s$)
[t_{outmin}, t_{outmax}]	Adjustment range of timeout period (s). t_{out_min} will be 0 for most EUTs
t_s	Settling time (s)

⁵⁰ Grid-centric nomenclature from IEC 61850-90-7 is adopted here.

⁵¹ This test follows the IEEE Std-1459-2000 reactive power sign convention, in which an overexcited power factor is positive and an underexcited power factor is negative.

⁵² The manufacturer's stated accuracy is necessary for some of the pass/fail criteria in certain grid codes, e.g., UL 1741 SA. It is also used for general acceptance criteria.

⁵³ This information can also be provided in tabular or function formats with active power limits vs SOC level.

4.3 Function Capability Table (FCT)

The INV4 function will be tested according to the present protocol. The Function Capability Table (FCT) should be filled out based on the capabilities of the EUT. If the EUT has the capability of acting on any of the optional parameters, then additional tests of those capabilities shall be performed, as indicated in the FCT.

Table 6. INV4 Function Capability Table

Test Type	ChgGrid	Timing	Tests to Include
INV4 domain	No	Default	Test 2 in Table 7
	Yes	Default	Tests 1 and 2 in Table 7
Time domain	Yes	t_R Enabled	Tests 3, 4, 9, and 10 in Table 8
	Yes	t_W Enabled	Tests 5, 6, 11 and 12 in Table 8
	Yes	t_{out} Enabled	Tests 7, 8, 13 and 14 in Table 8

4.4 INV4 Function Test Definitions

Table 7 and Table 8 suggest possible combinations of parameters to be tested. Performing all possible combinations may not be feasible. If an inverter does not have a particular capability, then those tests are run without configuring that function. All the tests must be performed in active power priority.

4.4.1 INV4 Test

The Request Active Power tests consist of in active power steps from zero active power to W_{MAXch} and from zero active power to W_{MAXdch} with active power steps about $5\% \cdot W_{MAXch}$ or $5\% \cdot W_{MAXdch}$. These tests should be repeated with reactive power set to $100\% \cdot Q_{MAXover}$ to $20\% \cdot Q_{MAXover}$ in steps of $20\% \cdot Q_{MAXover}$ and $100\% \cdot Q_{MAXunder}$ to $20\% \cdot Q_{MAXunder}$ in steps of $20\% \cdot Q_{MAXunder}$. Each power level must be held for the greater of 5 seconds and $2 \cdot t_s$.

Table 7. INV4 Test Matrix

#	P_{BESS}	Ramp time, t_R (s)	Time window, t_W (s)	Timeout, t_{out} (s)
1	0 to $100\% \cdot W_{MAXch}$ in steps of $5\% \cdot W_{MAXch}$	0	0	0
2	0 to $100\% \cdot W_{MAXdch}$ in steps of $5\% \cdot W_{MAXdch}$	0	0	0

4.4.2 INV4 Timing Test

The Request Active Power timing tests consist of two steps from zero active power to the maximum charge power W_{MAXch} and back to zero active power and from zero active power to the maximum discharge power W_{MAXdch} and back to zero active power. Each power step is held for a minimum test duration (timing interval) equal to the greater of 5 seconds and $2 \cdot (t_R + t_W +$

t_{out}) or $2 \cdot t_s$. The ramp times are calculated from the ramp rates using $t_R = 1/r_R$. If the maximum ramp time or maximum time window defined by the manufacturer exceeds 5 minutes, they may be changed to 5 minutes in order to complete the tests in a reasonable amount of time.

Table 8. INV4 Timing Setting Test Matrix

#	Ramp time, t_R (s)	Time window, t_w (s)	Timeout, t_{out} (s)
Default	0	0	0
t1	$t_{R_max}/2$	0	0
t2	t_{r_max}	0	0
t3	0	$t_{w_max}/2$	0
t4	0	t_{w_max}	0
t5	0	0	$t_{out_max}/2$
t6	0	0	t_{out_max}

4.5 INV4 Function Test Sequence

The Request Active Power from Storage test shall be carried out as follows:

Step 1: Prepare the EUT according to the following:

- Configure EUT and energy storage element according to Section 2.1.
- Connect to Utility Simulator with operation within nominal voltage range for a minimum of 5 minutes.
- Verify EUT is powered on to a level required to receive the command.
- Verify energy storage state of charge (SOC) will not interfere with INV4 tests. If the SOC is near SOC_{opMAX} or SOC_{opMIN} , charge or discharge the BESS system until close to: $(SOC_{opMAX} + SOC_{opMIN})/2$.
- Establish communication to EUT with Utility Management System Simulator.
- Record EUT output (e.g., voltage, current, power) with data acquisition system according to Section 2.2.
- Set Active and Reactive Power to zero.

Step 2: Request status from EUT and record the EUT parameters.

Step 3: Send default timing parameters to EUT according to Table 8.

Step 4: Confirm timing parameters are updated in the EUT.

Step 5: Send INV4 command according to Table 7.

Step 6: Record EUT response for the test duration, where the test duration is defined as the greater of 5 seconds and $2 \cdot t_s$.

Step 7: Repeat Steps 5-6 according to tests defined in Table 6 based on the FCT (INV4 domain tests).

Step 8: Set Active Power to zero.

Step 9: Step the commanded active power through the sequence: 0, W_{MAXch} , 0, W_{MAXdch} , 0 according to Section 4.4.1.

Step 10: Repeat Steps 8-9 with new the timing parameters based on the FCT (Timing tests).

Step 11. Repeat steps 3-10 with reactive power set to $100\% \cdot Q_{MAXover}$ to $20\% \cdot Q_{MAXover}$ in steps of $20\% \cdot Q_{MAXover}$ and $100\% \cdot Q_{MAXunder}$ to $20\% \cdot Q_{MAXunder}$ in steps of $20\% \cdot Q_{MAXunder}$.

Step 11: Analyze performance data.

4.6 Acceptance Criteria⁵⁴

Acceptance criteria are determined using the definitions provided in the grid code.

4.6.1 Default Requirements – Generic test Case

The maximum difference between the programmed power and response is less than or equal the manufacturer's stated power accuracy (MSA_p) plus the DAQ active power accuracy and the maximum difference between the programmed response time and actual response is less or equal than the manufacturer's stated time accuracy (MSA_t) plus the DAQ time accuracy.

4.6.2 Italian Technical rule

The maximum difference between the measured power and the set power is less than $\pm 2.5\%$ of W_{max} .

⁵⁴ As of now, only the Italian grid code requirements are available for this function.

5 Request Reactive Power (VV13)

5.1 Function Definition

This function requests the energy storage system to either sink or source reactive power as a percentage of the storage system's reactive power capacity. A battery simulator may be used in the test to reduce the time needed for the test by reducing charge and/or discharge times. It should be noted that charge/discharge requests are always subject to the state of charge, temperature, ramp rate limits, and other conditions of the battery. Therefore, the VV13 function should be executed only to the extent that the request is feasible.

This test procedure evaluates the test required in:

- CEI 0-21
- CEI 0-16
- EN 50438:2013
- IEC 61850-90-7

The differences in the grid codes for each of the VV13 functions is provided in Table 9.

Table 9. Review of Grid Codes for the VV13 Function

Country/ Grid Code	Data Requirements	Test Points	Time parameters
Italy/CEI 0-21: 2014-12 (LV) and Italy/CEI 0-16: 2014-12(MV)	P, Q, P _{dc} , cosφ measured (sample time 1s, data averaged at 1 min)	Q _{MAXover} , 0 and Q _{MAXunder} with active power from W _{MAXch} to W _{MAXdch} every 20% (33 test points)	No Time parameter
EN 50438:2013	P, Q, V _{rms} measured (sample time 200ms, data averaged at 1 min).	Q _{MAXover} , 0 and Q _{MAXunder} at active power output W _{MAXdch} at 50 % P _n	No Time parameters
International / IEC 61850-90-7⁵⁵	P, Q, V _{rms} measured (1 s average), communications recorded	VArMaxPct = 30, 50, 75, 100% of max VArS (only for Q _{MAXover}) with Active Power Output = 50, 90, 100% W _{MAXdch}	Ramp Rate, Time Window, Timeout

⁵⁵ Evaluated with the Sandia Interoperability Test Protocols.

5.2 Parameters

Before starting the VV13 test, the manufacturer and test engineer will determine the parameters within Table 10 and Table 11 for use in the procedure.

Table 10. VV13 Parameters

Parameter	Notes
QBESS	Requested reactive power output of the BESS device, expressed as a percentage of the BESS maximum reactive power capacity.
tW	Time window is an optional parameter in which the function is enabled after a delay. The delay can be random or fixed. If the time delay is zero, the command will execute immediately.
rR	Requested ramp rate (%Qrated/s) is an optional parameter defining the slope the EUT must move from the current set point to the new set point. The corresponding requested ramp time $tR=1/rR$ expresses the time for full execution.
tout	Timeout period is an optional parameter that defines the time after which the EUT will reset the VV13 function and set the reactive power to a default value. The default timeout period is indefinite (timeout period = 0 – Not Enable).

Table 11. Manufacturer Parameters

Parameter	Notes
W_{MAXch}	Maximum charge active power rating (W), negative value
W_{MAXdch}	Maximum discharge active power rating (W), positive value ⁵⁶
$Q_{MAXover}$	Maximum over excited reactive power rating (var), positive value ⁵⁷
$Q_{MAXunder}$	Maximum under excited reactive power rating (var), negative value
MSA_Q^{58}	Output reactive power accuracy (var or %var)
MSA_t	Accuracy of response time (s)
SOC_{opMAX}	Maximum operative state of charge at maximum reactive power (%) ⁵⁹
SOC_{opMIN}	Minimum operative state of charge at maximum reactive power (%)
$[t_{w_min}, t_{w_max}]$	Adjustment range of time window (s). t_{w_min} will be 0 for most EUTs.
$[r_{R_min}, r_{R_max}]$	Adjustment range of the ramp rate (% Q_{rated} /s)
$[t_{out_min}, t_{out_max}]$	Adjustment range of timeout period (s). t_{out_min} will be 0 for most EUTs.
t_s	Settling time (s)

5.3 Function Capability Table (FCT)

The VV13 function will be tested according to the present protocol. The Function Capability Table (FCT) (Table 12) should be filled out based on the capabilities of the EUT. If the EUT has the capabilities of acting on any of the optional parameters, then additional tests of those capabilities shall be performed, as indicated in the FCT.

Table 12. VV13 Function Capability

Test Type	Timing	Tests to Include
VV13 domain	Default	Tests 1 and 2 in Table 13
	t_R Enabled	Tests 3, 4, 9, and 10 in Table 14
Time domain	t_w Enabled	Tests 5, 6, 11 and 12 in Table 14
	t_{out} Enabled	Tests 7, 8, 13 and 14 in Table 14

5.4 VV13 Function Test Definitions

Table 13 and Table 14 provide possible combinations of parameters to be tested. Performing all possible combinations may not be feasible. If the EUT does not have a particular capability, then

⁵⁶ Grid-centric nomenclature from IEC 61850-90-7 is adopted here.

⁵⁷ This test follows the IEEE Std-1459-2000 reactive power sign convention, in which an overexcited power factor is positive and an underexcited power factor is negative.

⁵⁸ The manufacturer's stated accuracy is necessary for some of the pass/fail criteria in certain grid codes, e.g., UL 1741 SA. It is also used for general acceptance criteria.

⁵⁹ This information can also be provided in tabular or function formats with reactive power limits vs SOC level.

those tests are run without configuring that function. All the tests must be performed in reactive power priority.

5.5 VV13 Test

The Request Reactive Power tests consist of in reactive power steps from zero reactive power to $Q_{MAXover}$ and from zero reactive power to $Q_{MAXunder}$ with reactive power steps about $5\% \cdot Q_{MAXover}$ or $5\% \cdot Q_{MAXunder}$. These tests should be repeated with active power set to $100\% \cdot W_{MAXch}$ to 0 watts in steps of $20\% \cdot W_{MAXch}$ and $100\% \cdot W_{MAXdch}$ to $20\% \cdot W_{MAXdch}$ in steps of $20\% \cdot W_{MAXdch}$. Each power level must be held for the greater of 5 seconds and $2 \cdot t_s$.

Table 13. VV13 Test Matrix

#	Q_{BESS}	Ramp time, t_R (s)	Time window, t_w (s)	Timeout, t_{out} (s)
1	0 to $100\% \cdot Q_{MAXover}$ in steps of $5\% \cdot Q_{MAXover}$	0	0	0
2	0 to $100\% \cdot Q_{MAXunder}$ in steps of $5\% \cdot Q_{MAXunder}$	0	0	0

5.6 VV13 Timing Test

The Request Reactive Power timing tests consist of two steps from zero reactive power to the maximum overexcited reactive power $Q_{MAXover}$ and back to zero reactive power and from zero reactive power to the maximum underexcited power $Q_{MAXunder}$ and back to zero reactive power. Each power step is held for a minimum test duration (timing interval) equal to the greater of 5 seconds, $2 \cdot (t_R + t_w + t_{out})$, and $2 \cdot t_s$. The ramp times are calculated from the ramp rates using $t_R = 1/r_R$. If the maximum ramp time or maximum time window defined by the manufacturer exceeds 5 minutes, they may be changed to 5 minutes in order to complete the tests in a reasonable amount of time.

Table 14. VV13 Timing Setting Test Matrix

#	Ramp time, t_R (s)	Time window, t_W (s)	Timeout, t_{out} (s)
Default	0	0	0
t1	$t_{R_max}/2$	0	0
t2	t_{r_max}	0	0
t3	0	$t_{W_max}/2$	0
t4	0	t_{W_max}	0
t5	0	0	$t_{out_max}/2$
t6	0	0	t_{out_max}

5.7 VV13 Function test Sequence

The Request Reactive Power from Storage test shall be carried out as follows:

Step 1: Prepare the EUT according to the following.

- Configure EUT and energy storage element according to Section 2.
- Connect to Utility Simulator with operation within nominal voltage range for a minimum of 5 minutes.
- Verify EUT is powered on to a level required to receive the command.
- Verify energy storage state of charge (SOC) will not interfere with VV13 tests. If the SOC is near SOC_{opMAX} or SOC_{opMIN} , charge or discharge the BESS system until close to: $(SOC_{opMAX} + SOC_{opMIN})/2$.
- Establish communication to EUT with Utility Management System (UMS).
- Record EUT output (e.g., voltage, current, power) with data acquisition system according to Section 2.2.
- Set Active and Reactive Power to zero.

Step 2: Request status from EUT and record the EUT parameters.

Step 3: Send default timing parameters to EUT according to Table 14.

Step 4: Confirm timing parameters are updated in the EUT.

Step 5: Send VV13 command according to Table 13 based on the FCT.

Step 6: Record EUT response for the test duration, where the test duration is defined as the greater of 5 seconds and $2 \cdot t_S$.

Step 7: Repeat Steps 5-6 according to the tests defined in Table 13 (VV13 domain tests).

Step 8: Set Reactive Power to zero.

Step 9: Step the commanded reactive power through the sequence 0, $Q_{MAXover}$, 0, $Q_{MAXunder}$, 0 according to Section 5.6.

Step 10: Repeat Steps 8-9 with new the timing parameters based on the FCT (Timing tests).

Step 11: Repeat steps 3-9, with reactive power set to $100\% \cdot W_{MAXch}$ to $20\% \cdot W_{MAXch}$ in steps of $20\% \cdot W_{MAXch}$ and $100\% \cdot W_{MAXdch}$ to $20\% \cdot W_{MAXdch}$ in steps of $20\% \cdot W_{MAXdch}$.

Step 12: Analyze performance data.

5.8 Acceptance Criteria

Acceptance criteria are determined using the definitions provided in the grid code.

5.8.1 Default Requirements – Generic test case

The maximum difference between the programmed reactive power and response is less or equal than the manufacturer's stated power accuracy (MSA_Q) plus DAQ reactive power accuracy and the maximum difference between the programmed response time and actual response is less or equal than the manufacturer's stated time accuracy (MSA_t) plus DAQ time accuracy.

5.8.2 Italian Technical Rules

The maximum difference between the measured reactive power and the set reactive power is less than $\pm 5\%$ of the EUT nameplate apparent power and the Power Factor deviation is less than ± 0.02 .

5.8.3 EN 50438:2013

The maximum difference between the measured reactive power and the set reactive power is less than $\Delta Q < \pm 5\%$ of the EUT nameplate active power

5.8.4 CLC/TS 50549

The maximum difference between the measured reactive power and the set reactive power is less than $\Delta Q < \pm 2\%$ of the EUT nameplate apparent power in the range 10% - 100% of nameplate apparent power.

6 Commanded Power Factor Test (INV3)

6.1 Function Definition

This function sets the power factor (i.e., Displacement Factor, $\cos\phi$) angle in response to a command from the utility controller or a combination of local conditions, modes, schedules, etc. A ramp rate and a delay time before starting may also be included. A timeout period may be included for reverting to the default state of the EUT.

This test procedure evaluates the functionality required in:

- IEC 61850-90-7
- California Rule 21/UL 1741 SA

The differences in the grid codes for each of the VV13 functions is provided in Table 15.

Table 15. Review of Grid Codes for the INV3 Function

Country/ Grid Code	Data Requirements	Test points	Time parameters
California/ UL 1741 SA: 2016	P, Q measured, $\cos\phi$ calculated	<ul style="list-style-type: none"> - 1.0 - $PF_{min,ind}$ - $PF_{mid,ind}$ - $PF_{min,cap}$ - $PF_{mid,cap}$ 	No timing parameters
International/ IEC 61850-90-7⁶⁰	P, Q measured (1 s average), communications recorded	<ul style="list-style-type: none"> - 1.00 (default) - $PF_{min,cap}$ (e.g., 0.80 Overexcited) - $PF_{min,ind}$ (e.g., 0.80 Underexcited) - $PF_{min,cap} / 2 + 0.5$ (e.g., 0.90 Overexcited) - $PF_{mid,ind} / 2 + 0.5$ (e.g., 0.90 Underexcited) 	Ramp Rate, Time Window, Timeout

6.2 Parameters

Before starting the PF test, the following parameters will be determined by the manufacturer and test engineer for use in the procedure.

⁶⁰ Evaluated with the Sandia Interoperability Test Protocols.

Table 16. INV3 Function Capability

Parameter	Notes
PF_{BESS}	Requested power factor of the BESS device, expressed as a number between 0 and 1.
t_w	Time window is an optional parameter in which the function is enabled after a delay. The delay can be random or fixed. If the time delay is zero, the command will execute immediately.
r_R	Requested ramp rate (%Prated/s) is an optional parameter defining the slope the EUT must move from the current set point to the new set point. The corresponding Requested ramp time t _R express the time for action completion.
t_{out}	Timeout period is an optional parameter that defines the time after which the EUT will reset the commanded power function and set the power factor to a default value. The default timeout period is indefinite (timeout period = 0 – Not Enable).

Table 17. Manufacturer Parameters

Parameter	Notes
W_{MAXch}	Maximum charge active power rating (W), negative value
W_{MAXdch}	Maximum discharge active power rating (W), positive value ⁶¹
Q_{MAXover}	Maximum over excited reactive power rating (var), positive value ⁶²
Q_{MAXunder}	Maximum under excited reactive power rating (var), negative value
MSA_t ⁶³	Accuracy of time (s)
MSA_{PF}	Power Factor Accuracy
SOC_{opMAX}	Maximum operative state of charge at maximum charge power (%) ⁶⁴
SOC_{opMIN}	Minimum operative state of charge at maximum discharge power (%)
[tw_{min}, tw_{max}]	Adjustment range of time window (s).
[r_{Rmin}, r_{Rmax}]	Adjustment range of the ramp rate (PF/s)
[tout_{min}, tout_{max}]	Adjustment range of timeout period (s)
ts	Settling time (s)
PF_{minunder}	Minimum Underexcited Power Factor ⁶⁵
PF_{minover}	Minimum Overexcited Power Factor

⁶¹ Grid-centric nomenclature from IEC 61850-90-7 is adopted here.

⁶² This test follows the IEEE Std-1459-2000 reactive power sign convention, in which an overexcited power factor is positive and an underexcited power factor is negative.

⁶³ The manufacturer's stated accuracy is necessary for some of the pass/fail criteria in certain grid codes, e.g., UL 1741 SA. It is also used for general acceptance criteria.

⁶⁴ This information can also be provided in tabular or function formats with active power limits vs SOC level.

⁶⁵ This test follows the concepts of reactive power sign convention in which a capacitive, overexcited power factor is positive and an inductive, underexcited power factor is negative.




Figure 4. Example target PF for an EUT with 'Active Power Priority' enabled.

Additionally the following parameters will be calculated:

- $P_x = S_{rated} \cdot PF$ is the maximum active power which an 'Active Power Priority' mode maintains the PF command. Active power ratings above this value in 'Active Power Priority' will result in PF values closer to unity.
- $P_{low} = 0.2 \cdot S_{rated}$ unless stated otherwise by the equipment manufacturer.
- $PF_{midover} = (1 - PF_{minover})/2$, half the EUT overexcited range.
- $PF_{midunder} = (1 - PF_{minunder})/2$, half the EUT underexcited range.

6.3 Function Capability Table (FCT)

The INV3 function will be tested according to the EUT capabilities. The Function Capability Table (FCT) (Table 18) should be filled out based on the capabilities of the EUT. If the EUT has the capabilities of acting on any of the optional parameters, then additional tests of those capabilities shall be performed, as indicated in the FCT.

Table 18. INV3 Function Capability

Test Type	Timing	Tests to Include
INV3 domain	Default	Tests 1-5 in Table 19
	t_R Enabled	Tests t1 and t2 in Table 20
Time domain	t_W Enabled	Tests t3 and t4 in Table 20
	t_{out} Enabled	Tests t5 and t6 in Table 20Table 14

6.4 INV3 Function Test Definition

Table 19 and Table 20 provide possible combinations of parameters to be tested. Performing all possible combinations may not be feasible. If the EUT does not have a particular capability, then those tests are run without configuring that function. All the tests must be performed in active power priority.

6.4.1 INV3 Test

The Commanded Power Factor tests consist in active power steps $-W_{MAXch}$, $-(W_{MAXch}+P_X)/2$, $-P_X$, $-(P_X+P_{low})/2$, $-P_{low}$, 0 , P_{low} , $(P_X+P_{low})/2$, P_X , $(W_{MAXdch}+P_X)/2$ and W_{MAXdch} , executed with different values of Power Factor, in accordance with Table 19. Each power level must be held for the greater of 5 seconds and $2 \cdot t_s$.

Table 19. INV3 Test Matrix

#	PF _{BESS}	Ramp time, t_R (s)	Time window, t_W (s)	Timeout, t_{out} (s)
1	1	0	0	0
2	PF _{midover}	0	0	0
3	PF _{minover}	0	0	0
4	PF _{midunder}	0	0	0
5	PF _{minunder}	0	0	0

6.4.2 INV3 Timing Test

The Commanded Power Factor timing tests consist of two steps from power factor equal to unity to the minimum overexcited power factor PF_{minover} and back to unity and from power factor equal to unity to the minimum underexcited power factor PF_{minunder} and back to unity, performed with active power set to P_X and $-P_X$. Each power step is held for a minimum test duration (timing interval) equal to the greater of 5 seconds and $2 \cdot (t_R + t_W + t_{out})$ or $2 \cdot t_s$. The ramp times are calculated from the ramp rates using $t_R = 1/r_R$. If the maximum ramp time or maximum time window defined by the manufacturer exceeds 5 minutes, they may be changed to 5 minutes in order to complete the tests in a reasonable amount of time.

Table 20. INV3 Timing Setting test Matrix

#	Ramp time, t_R (s)	Time window, t_W (s)	Timeout, t_{out} (s)
Default	0	0	0
t1	$t_{R_max}/2$	0	0
t2	t_{R_max}	0	0
t3	0	$t_{W_max}/2$	0
t4	0	t_{W_max}	0
t5	0	0	$t_{out_max}/2$
t6	0	0	t_{out_max}

6.5 INV3 Function test Sequence

The commanded power factor test shall be carried out as follows:

Step 1: Prepare the EUT according to the following:

- Configure EUT and energy storage element according to Section 2.
- Connect to Utility Simulator with operation within nominal voltage range for a minimum of 5 minutes.
- Verify EUT is powered on to a level required to receive the command.
- Verify energy storage state of charge (SOC) will not interfere with VV13 tests. If the SOC is near SOC_{opMAX} or SOC_{opMIN} , charge or discharge the BESS system until close to: $(SOC_{opMAX} + SOC_{opMIN})/2$.
- Establish communication to EUT with Utility Management System (UMS).
- Record EUT output (e.g., voltage, current, power) with data acquisition system according to Section 2.2.
- Set Active and Reactive Power to zero.

Step 2: Request status from EUT and record the EUT parameters.

Step 3: Send default timing parameters to EUT according to Table 20.

Step 4: Confirm timing parameters are updated in the EUT.

Step 5: Set the EUT active power to required power level (starting value 0).

Step 6: Send INV3 Power Factor settings according to the test required in Table 19.

Step 7: Record EUT response for the test duration, where the test duration is defined as the greater of 5 seconds and $2 \cdot t_s$.

Step 8: Repeat Steps 3-7 with the EUT active power set to $-W_{MAXch}$, $-(W_{MAXch}+P_X)/2$, $-P_X$, $-(P_X+P_{low})/2$, $-P_{low}$, 0 , P_{low} , $(P_X+P_{low})/2$, P_X , $(W_{MAXdch}+P_X)/2$ and W_{MAXdch} .

Step 9: Repeat Steps 3-8 according to the tests defined in Table 19 (INV3 domain tests).

Step 10: Set Active Power to P_X or to $-P_X$.

Step 11: Step the commanded Power Factor through the sequence: unity, $PF_{minover}$, unity, $PF_{minunder}$, unity according to Section 6.4.2.

Step 12: Repeat Steps 10-11 with new the timing parameters based on the FCT (Timing tests).

Step 13: Analyze performance data.

6.6 Acceptance Criteria

Acceptance criteria are determined using the definitions provided in the grid code.

6.6.1 Default Criteria

The maximum difference between the measured power factor and the PF setting must be less than $MSAPF$ plus the DAS PF accuracy. The maximum difference between the measured time response and the time response settings must be less than MSA_t plus the DAS time accuracy.

7 Frequency/Watt “P(f)” Test (FW)

7.1 Function Definition

FW function enables the inverter to have multiple curves which describe limits placed on power production/absorption based on frequency changes; one or more frequency-watt curves are used to *control* active power generation and charging (in the case of a storage system). If frequency increases, power generation is reduced (and, if requested, also charging is enabled) to maintain nominal grid frequency. If frequency falls, storage charging rates are limited (and if requested also discharge and power generation is activated) to maintain nominal grid frequency.

Frequency-triggered management is used to mitigate grid frequency deviations by increasing or decreasing power supplied by the DER. Such actions may be taken during emergency conditions, or this capability may be used during normal operations to “smooth” minor frequency variations, such as in a microgrid.

This function is defined for a general case applicable to all codes or rules. Parameter and test matrixes definition takes into account specific national requirements. In particular the test procedure evaluates the functionality required in:

- CEI 0-21
- CEI 0-16
- IEC 61850-90-7
- UL 1741 SA
- CLC/TS 50549:2015
- EN-50438:2013
- VDE-AR-N 4105:2011.

Table 21. Review of Grid Codes for the Freq-Watt Function

Country/ Grid Code	Data Requirements	Specified Curve	Time Parameters
Italy/CEI 0-21: 2014-12 (LV) and Italy/CEI 0-16: 2014-12(MV)	P, f measured (0.2 s average)	The external FW profile is: (50 Hz, W_{MAXdch}); (50.3 Hz, W_{MAXdch}); (51.5 Hz, W_{MAXch}); (50 Hz, W_{MAXch}); (49.7 Hz, W_{MAXch}); (47.5 Hz, W_{MAXdch}) Hysteresis Enable, Tie Line Enable, QuadExit Enable	Time window, Recovery ramp rate, Recovery delay
International / IEC 61850-90-7⁶⁶	P, f_{rms} measured (1 s average), communications recorded	Multiple curves, e.g., Test 1: $F_1 = 100.3\%$, $PG_1 = 0\% W_{MAXdch}$ $F_2 = 101.7\%$, $PG_2 = -15\% W_{MAXdch}$ $F_3 = 104.0\%$, $PG_3 = -80\% W_{MAXdch}$	Ramp Rate, Time Window, Timeout
US California/ UL 1741 SA: 2016	P, f measured	Multiple curves $F_1 = f_{start_min}$, $PG_1 = W_{MAXdch}$ $F_2 = f_{start_min} + 100\%P_{rated}/K_{Power-Freq}$, $PG_2 = 0\%$	
EN 50438:2013	P, f measured	Programmable tie line and droop (power gradient) required for BESS during power export (discharge) . Default setting is provided by DSO or national codes/rules. Quadrant 1: Tie line $Hz_{TL,hi}$ between 50.2 to 52 Hz Power Gradient PG between 16.7% to 100% $P_{HzTL,hi}$ per Hz	Recovery Ramp Rate

⁶⁶ Evaluated with the Sandia Interoperability Test Protocols.

<p>CLC/TS 50549: 2015-01</p>	<p>P,f measured</p>	<p>Programmable tie line and droop (power gradient) required for BESS during power export (discharge). Default setting is provided by DSO or national codes/rules.</p> <p>Quadrant 1: (Low Voltage & Medium Voltage)</p> <p>Tie line Hz_{TL,hi} ,recommended between 50.2 to 50.5 Hz (Default 50.2 Hz)</p> <p>Power Gradient PG between 16.7% to 100% (PHz_{TL,hi} or W_{MAXdch}) per Hz (Default 80%)</p> <p>Quadrant 2: (Medium Voltage only – if generator operates below max. available power output)</p> <p>Tie line Hz_{TL,lo} ,recommended between 49.8 to 49.5 Hz</p> <p>Power Gradient PG between 16.7% to 100% (PHz_{TL,hi} or W_{MAXdch}) per Hz</p>	<p>Recovery Ramp Rate, Time Window</p>
<p>VDE-AR-N 4105:2011</p>	<p>P,f measured</p>	<p>Quadrant 1: Tie line Hz_{TL} = 50.2 Hz PG = 40 % PHz_{TL,hi} per Hz for BESS during power export (discharge)</p>	<p>Recovery Ramp Rate</p>

7.2 Parameters

Before starting the FW test, the following parameters will be determined by the manufacturer and test engineer for use in the procedure.

Table 22. FW Parameters

Parameter	Notes
FW Curve y^{67}	Arrays of $(F_x, P_x)_y$ pairs where x is the point number and y is the FW quadrant.
FW Curve y_h	Arrays of $(F_x, P_x)_{yh}$ pairs where x is the point number, y is the FW quadrant, and h indicates a hysteresis curve.
TL	Tie-line setting: when the tie-line is enabled the EUT must follow a line from the EUT power at F_{n-1} to (F_n, P_n) for curve 1 and must follow a line from the EUT power at F_2 to (F_1, P_1) for curve 3. See Figure 8 for an illustrative example of operation with tie-lines enabled.
H_{ZTL,hi}	AC over-frequency where tie-line effect begins (Hz)
H_{ZTL,lo}	AC under-frequency where tie-line effect begins (Hz)
QuadExit	When enabled, the EUT is required to reverse the active power flow to compensate for the frequency deviation.
H_{ysenable}	Turn on/off Hysteresis
tw	Time window is an optional parameter in which the function is enabled after a delay. The delay can be random or fixed. If the time delay is zero, the command will execute immediately.
r_R	Requested ramp rate ($\%P_{rated}/s$) is an optional parameter defining the slope the EUT must move from the current set point to the new set point. The corresponding Requested ramp time $t_R=1/r_R$ expresses the time for full execution.
t_{RD}	Recovery delay is an optional parameter expressing the minimum waiting time during the recovery phase.
r_{Rec}	Recovery ramp rate ($\%P_{rated}/s$) is an optional parameter defining how quickly the EUT output returns to normal (default) values after frequency reenters into the no-regulation range. The corresponding recovery ramp time, $t_{Rec}=1/r_{Rec}$ expresses the time for full execution.
t_{out}	Timeout period is an optional parameter that defines the time after which the EUT will reset the frequency-watt function and set the active power to a default value. The default timeout period is indefinite (timeout period = 0 – Not Enable).

⁶⁷ While it is possible for FW function reference parameters to be specified in a number of ways in the grid code or EUT, for this protocol, the FW curves will be defined with (F, P) points.

Table 23. Manufacturer Parameters

Parameter	Notes
W_{MAXch}	Maximum charge active power rating (W), negative value
W_{MAXdch}	Maximum discharge active power rating (W), positive value ⁶⁸
[Hz_{min}, Hz_{max}]	AC frequency allowed operating range (Hz)
Hz_{nom}	AC nominal frequency (Hz)
MSA_{Hz} ⁶⁹	AC frequency accuracy (Hz or %Hz)
MSA_w	Output Power accuracy (W or %W)
MSA_t	Accuracy of time (s)
SOC_{opMAX}	Maximum operative state of charge at maximum charge power (%) ⁷⁰
SOC_{opMIN}	Minimum operative state of charge at maximum discharge power (%)
[t_{w_min}, t_{w_max}]	Adjustment range of time window (s). t _{w_min} will be 0 for most EUTs.
[r_{R_min}, r_{R_max}]	Adjustment range of the ramp rate (%P _{rated} /s)
[t_{RD_min}, t_{RD_max}]	Adjustment range of recovery delay time (s). t _{RD_min} will be 0 for most EUTs.
[r_{Rec_min}, r_{Rec_max}]	Adjustment range of the rate of return to normal operation (%P _{rated} /s)
[t_{out_min}, t_{out_max}]	Adjustment range of timeout period (s). t _{out_min} will be 0 for most EUTs.
t_s	Settling time (s)

FW allows more than one frequency-watt curve to be specified. Furthermore, frequency-watt settings may be different in under or over frequency conditions. In order to define FW inverter response, set-up parameters must be configured in the EUT.

⁶⁸ Grid-centric nomenclature from IEC 61850-90-7 is adopted here.

⁶⁹ The manufacturer's stated accuracy is necessary for some of the pass/fail criteria in certain grid codes, e.g., UL 1741 SA. It is also used for general acceptance criteria.

⁷⁰ This information can also be provided in tabular or function formats with active power limits vs SOC level.




Figure 5. Example FW points definition.




Figure 6. Example FW curves.

In quadrants 1 and 4 there is an example of asymmetric hysteresis and in quadrants 2 and 3 there is an example of symmetric hysteresis.




Figure 7. Example FW response with hysteresis, QuadExit = 1, and TL = 0.




Figure 8. Example FW response with no hysteresis, QuadExit = 1, and TL = 1.

Depending on grid code, timing parameters can assume different values. The following two figures show the FW function time domain behavior in under-frequency and in over-frequency. Examples with and without hysteresis are included. Also the timing response of the FW function with timing parameters set to zero is shown.




Figure 9. Time domain FW function – Asymmetric Hysteresis Disabled in under-frequency (left side) and in over-frequency (right side).




Figure 10. Time domain FW function – Asymmetric Hysteresis Enabled in under-frequency (left side) and in over-frequency (right side).

7.3 Function Capability Table (FCT)

The FCT should be filled out based on the capabilities of the EUT. Two different tests are foreseen: FW Domain Test and Time Domain Test. The possible FW modes to be tested depend on:

- Tie-line setting
- QuadExit
- Hysteresis
- Timing parameters:
 - ramp time, t_R
 - recovery delay time, t_{RD}

- recovery ramp time, t_{Rec}
- time window, t_w
- timeout, t_{out} .

For a general testing, the FCT tables are in Table 24 and Table 25; specific rules/codes test are also included. Generally, not all tests are required: depending on FW modes, it is possible to choose the corresponding FW test curves.

Table 24. Function Capability Table for FW Domain test

Test Type	Hysteresis	Quad Exit	Tie Line	FW test number
FW domain	No	No	No	Test #1 in Table 27
	No	Yes	No	Test #2 in Table 27
	No	No	Yes	Test #3 in Table 27
	No	Yes	Yes	Test #4 in Table 27
	Yes	No	No	Test #5 in Table 27
	Yes	Yes	No	Test #6 in Table 27
	Yes	No	Yes	Test #7 in Table 27
	Yes	Yes	Yes	Test #8 in Table 27

Table 25. Function Capability Table for FW Timing test

Test Type	Hysteresis	Time window & Ramp time	Timeout	Timing test number
Time domain	No	No	No	Test #t1 default in Table 28
	No	Yes	No	Test #t2 and Test #t3 in Table 28
	Yes	No	No	Test #t4 and Test #t5 in Table 28
	Yes	Yes	No	Test #t6 and Test #t7 in Table 28
	No	No	Yes	Test #t8 and Test #t9 in Table 28

7.4 FW Function Test Definition

7.4.1 FW Domain Test

FW domain test verifies the EUT operation according to the required test condition as defined in FCT (Table 24). Test will be performed setting up the EUT on the basis of the FW test curves as in Table 26. Each test is executed at eleven different starting active power levels ranging from W_{MAXch} and W_{MAXdch} , with reactive power set to 0. For each power level, test is carried out at

different frequency values adjusted, with a grid simulator, between $H_{z_{min}} + \Delta f$ ⁷¹ and $H_{z_{max}} - \Delta f$ in order to avoid the EUT disconnection at the frequency limits. Along each of the FW trajectory lines defined by FW test curves a minimum of 5 points⁷² is required. Each point must be held for the greater of 5 seconds and $2 \cdot t_s$. Figure 10 shows an example of the frequency test points required.




Figure 11. Frequency points required for FW Domain tests.

The points are traced with the grid simulator to reach the hysteresis values.

Where the value H_{z1} , H_{z2} , H_{z3} and H_{z4} can be defined as follow:

$$H_{z1} = H_{z_{nom}} + 0.3^{73} \cdot (H_{z_{Max}} - H_{z_{nom}}) \text{ (over-frequency regulation threshold)}$$

$$H_{z2} = H_{z1} + \frac{H_{z_{Max}} - H_{z1}}{W_{MAXdch} - W_{MAXch}} \cdot W_{MAXdch} \text{ (over-frequency curve 1 and curve 4 intersection point)}$$

$$H_{z3} = H_{z_{nom}} - 0.3 \cdot (H_{z_{nom}} - H_{z_{min}}) \text{ (under-frequency regulation threshold)}$$

$$H_{z4} = H_{z3} - \frac{H_{z3} - H_{z_{Min}}}{W_{MAXdch} - W_{MAXch}} \cdot -W_{MAXch} \text{ (under-frequency curve 2 and curve 3 intersection point)}$$

⁷¹ Δf is calculated as the composed accuracy of the EUT frequency measurement accuracy and the grid simulator frequency setup accuracy. A typical value defined in codes/rules could be about 10 mHz.

⁷² This can be adjusted if National Codes/Rules require a different number of points. A minimum of three frequency settings will be used, but additional test points maybe necessary. The frequency between points should be large enough to resolve the watt accuracy of the EUT for the function.

⁷³ This value can be changed according to specific codes/rules request

Table 26. FW Test Curves

		Format: $P(f) = [(f_x, P_x)_y]$ where y is the quadrant
Generic FW and Hysteresis Test Curves	FW Test Curve 1	Quadrant 1: $[(H_{Z_{nom}}, W_{MAXdch})_1; (H_{Z_1}, W_{MAXdch})_1; (H_{Z_2}, 0)_1; (H_{Z_{max}}, 0)_1]$ Quadrant 2: $[(H_{Z_{nom}}, W_{MAXdch})_2; (H_{Z_{min}}, W_{MAXdch})_2; (H_{Z_{min}}, 0)_2]$ Quadrant 3: $[(H_{Z_{nom}}, W_{MAXch})_3; (H_{Z_3}, W_{MAXch})_3; (H_{Z_4}, 0)_3; (H_{Z_{min,r}}, 0)_3]$ Quadrant 4: $[(H_{Z_{nom}}, W_{MAXch})_4; (H_{Z_{max}}, W_{MAXch})_4; (H_{Z_{max}}, 0)_4]$
	FW Test Curve 2	Quadrant 1: $[(H_{Z_{nom}}, W_{MAXdch})_1; (H_{Z_1}, W_{MAXdch})_1; (H_{Z_2}, 0)_1]$ Quadrant 2: $[(H_{Z_{nom}}, W_{MAXdch})_2; (H_{Z_{min}}, W_{MAXdch})_2; (H_{Z_4}, 0)_2]$ Quadrant 3: $[(H_{Z_{nom}}, W_{MAXch})_3; (H_{Z_3}, W_{MAXch})_3; (H_{Z_4}, 0)_3]$ Quadrant 4: $[(H_{Z_{nom}}, W_{MAXch})_4; (H_{Z_{max}}, W_{MAXch})_4; (H_{Z_2}, 0)_4]$
	Hysteresis Test Curve 1	Quadrant 1: $[(H_{Z_{max}}, 0)_{1h1}; (H_{Z_2}, 0)_{1h1}; (H_{Z_{HysHi}}, 0)_{1h1}; (H_{Z_{HysHi}}, W_{MAXdch})_{1h1}; (H_{Z_{nom}}, W_{MAXdch})_{1h1}]$ Quadrant 2: $[(H_{Z_{min}}, W_{MAXdch})_{2h}; (H_{Z_{HysLo}}, W_{MAXdch})_{2h}; (H_{Z_{HysLo}}, 0)_{2h}]$ Quadrant 3: $[(H_{Z_{min}}, 0)_{3h}; (H_{Z_3}, 0)_{3h}; (H_{Z_{HysLo}}, 0)_{3h}; (H_{Z_{HysLo}}, W_{MAXch})_{3h}; (H_{Z_{nom}}, W_{MAXch})_{3h}]$ Quadrant 4: $[(H_{Z_{max}}, W_{MAXch})_{4h}; (H_{Z_{HysHi}}, W_{MAXch})_{4h}; (H_{Z_{HysHi}}, 0)_{4h}]$
	Hysteresis Test Curve 2	Quadrant 1: $[(H_{Z_{max}}, 0)_{1h}; (H_{Z_{HysHi}}, 0)_{1h}; (H_{Z_{HysHi}}, W_{MAXdch})_{1h}; (H_{Z_2}, W_{MAXdch})_{1h}]$ Quadrant 2: $[(H_{Z_{min}}, W_{MAXdch})_{2h}; (H_{Z_{HysLo}}, W_{MAXdch})_{2h}; (H_{Z_{HysLo}}, 0)_{2h}]$ Quadrant 3: $[(H_{Z_4}, 0)_{3h}; (H_{Z_{HysLo}}, 0)_{3h}; (H_{Z_{HysLo}}, W_{MAXch})_{3h}; (H_{Z_{nom}}, W_{MAXch})_{3h}]$ Quadrant 4: $[(H_{Z_{max}}, W_{MAXch})_{4h}; (H_{Z_{HysHi}}, W_{MAXch})_{4h}; (H_{Z_{HysHi}}, 0)_{4h}]$
Grid Code Specific FW and Hysteresis Test Curves	CEI 0-16/21 FW Test Curve	Quadrant 1: $[(H_{Z_{nom}}, W_{MAXdch})_1; (100.6, W_{MAXdch})_1; (101.8, 0)_1]$ Quadrant 2: $[(H_{Z_{nom}}, W_{MAXdch})_2; (98.2, W_{MAXdch})_2; (98.8, 0)_2]$ Quadrant 3: $[(H_{Z_{nom}}, W_{MAXch})_3; (99.4, W_{MAXch})_3; (98.8, 0)_3]$ Quadrant 4: $[(H_{Z_{nom}}, W_{MAXch})_4; (103, W_{MAXch})_4; (101.8, 0)_4]$
	CEI 0-16/21 Hysteresis Test Curve	Quadrant 1: $[(H_{Z_{nom}}, W_{MAXdch})_{1h1}; (100.2, W_{MAXdch})_{1h1}; (100.2, 0)_{1h1}]$ Quadrant 2: $[(98.2, W_{MAXdch})_{2h2}; (99.8, W_{MAXdch})_{2h2}; (99.8, 0)_{2h2}]$ Quadrant 3: $[(H_{Z_{nom}}, W_{MAXch})_{3h3}; (99.8, W_{MAXch})_{3h3}; (99.8, 0)_{3h3}]$ Quadrant 4: $[(103, W_{MAXch})_{4h4}; (100.2, W_{MAXch})_{4h4}; (100.2, 0)_{4h4}]$
	VDE 4105 FW Test Curve	Quadrant 1: $[(H_{Z_{nom}}, W_{MAXdch})_1; (100.4, W_{MAXdch})_1; (103, 0.52 \cdot W_{MAXdch})_1; (103, 0)_1]$ Quadrant 2: $[(97, W_{MAXdch})_2; (H_{Z_{nom}}, W_{MAXdch})_2;]$
	IEC 61850-90-7 FW Test Curve	Quadrant 1: $[(H_{Z_{nom}}, W_{MAXdch})_1; (100.3, W_{MAXdch})_1; (101.7, 0.85 \cdot W_{MAXdch})_1; (104, 0.2 \cdot W_{MAXdch})_1]$

Table 27. FW Test Matrix

	Test #	Curves		Hz _{TL,hi}	Hz _{TL,lo}
		FW Curve ⁷⁴	Hysteresis Curve		
Generic FW and Hysteresis Test Curves	1	FW Test Curve 1			
	2	FW Test Curve 2			
	3	FW Test Curve 1		Hz ₁	Hz ₃
	4	FW Test Curve 2		Hz ₁	Hz ₃
	5	FW Test Curve 1	Hysteresis Test Curve 1		
	6	FW Test Curve 2	Hysteresis Test Curve 2		
	7	FW Test Curve 1	Hysteresis Test Curve 1	Hz ₁	Hz ₃
	8	FW Test Curve 2	Hysteresis Test Curve 2	Hz ₁	Hz ₃
Grid Code Specific FW and Hysteresis Test Curves	9	CEI 0-16/21 FW Test Curve	CEI 0-16/21 Hysteresis Test Curve	100.6 (e.g., 50.3 Hz)	99.4 (e.g., 49.7 Hz)
	10	VDE 4105 FW Test Curve		100.4 (e.g., 50.2 Hz)	
	11	IEC 61850-90-7 FW Test Curve		100.3	

7.4.2 FW Timing Test

The Frequency-Watt timing tests consist of two steps from the nominal frequency to Hz_{min} + Δf and back to nominal frequency or from the nominal frequency to Hz_{max} – Δf and back to nominal frequency. Each frequency step is held for a minimum test duration (timing interval) equal to the greater of 5 seconds and 2·(t_R + t_{RD} + t_{Rec} + t_W + t_{out}) or 2·t_S, as defined in Table 22 and in Figure 9 and Figure 10.

⁷⁴ FW Test Curves are defined in Table 26.

Table 28. FW Timing Setting Test Matrix⁷⁵

	Test #	Ramp time, t_R (s)	Recovery Delay time, t_{RD} (s)	Recovery ramp time, t_{Rec} (s)	Time window, t_w (s)	Timeout, t_{out} (s)
Generic FW and Hysteresis Test Curves	t1 DEFAULT	0	0	0	0	0
	t2	$t_{R_max}/2$	0	0	$t_{w_max}/2$	0
	t3	t_{R_max}	0	0	t_{w_max}	0
	t4	0	$t_{RD_max}/2$	$t_{Rec_max}/2$	0	0
	t5	0	t_{RD_max}	t_{Rec_max}	0	0
	t6	$t_{R_max}/2$	$t_{RD_max}/2$	$t_{Rec_max}/2$	$t_{w_max}/2$	0
	t7	t_{R_max}	t_{RD_max}	t_{Rec_max}	t_{w_max}	0
	t8	0	0	0	0	$t_{out_max}/2$
	t9	0	0	0	0	t_{out_max}
Grid Code Specific FW and Hysteresis Test Curves	1 (CEI 0-16/21)	0	300	300	0	0
	2 (CEI 0-16/21)	0	300	300	1	0
	EN-50530:2013 VDE-4105:2011	0	0	$\frac{60\text{ s}}{10\% W_{MAXdch}}$	0	0
	CLC/TS 50549-(1,2):2015	0	0	0	0 to 2	0

7.5 FW Function test Sequence

The FW test shall be carried out as follows:

Step 1: Prepare the EUT according to the following:

- Configure EUT and energy storage element according to Section 2.1.
- Connect to Utility Simulator with operation within nominal voltage range for a minimum of 5 minutes.
- Verify EUT is powered on to a level required to receive the command.

⁷⁵ The test must be repeated starting from different power levels; a minimum of five is necessary.

- Verify energy storage state of charge (SOC) will not interfere with FW tests. If the SOC is near SOC_{opMAX} or SOC_{opMIN} , charge or discharge the BESS system until close to: $(SOC_{opMAX} + SOC_{opMIN})/2$.
- Establish communication to EUT with Utility Management System (UMS).
- Record EUT output (e.g., voltage, current, power) with data acquisition system according to Section 2.2.
- Set Reactive Power to zero.

Step 2: Request status from EUT and record the EUT parameters.

Step 3: Send FW (F, P) pairs according to required test as in Table 26.

Step 4: Confirm FW parameters are updated in the EUT.

Step 5: Send default timing parameters to EUT according to Table 28.

Step 6: Set the EUT power to required power level (starting value 0).

Step 7: Adjust the grid frequency to the required grid frequency points: 5 points per line including also line to $Hz_{min} + \Delta f$ and $Hz_{max} - \Delta f$ points. The tests will follow this sequence: Hz_{nom} to $Hz_{max} - \Delta f$ to Hz_{nom} to $Hz_{min} + \Delta f$ and to Hz_{nom} .

Step 8: Set the timing parameters according to Table 28.

Step 9: Step the grid frequency to $Hz_{min} + \Delta f$ and $Hz_{max} - \Delta f$ according to Section 7.4.2.

Step 10: Repeat Steps 8-9 new the timing parameters based on the FCT (Timing tests).

Step 11: Repeat Steps 5-10 with the EUT power set to $100\% \cdot W_{MAXch}$ to $20\% \cdot W_{MAXch}$ in steps of $20\% \cdot W_{MAXch}$ and $100\% \cdot W_{MAXdch}$ to $20\% \cdot W_{MAXdch}$ in steps of $20\% \cdot W_{MAXdch}$.

Step 12: Repeat Steps 3-11 with FW new pairs based on the FCT (FW domain tests).

Step 13: Analyze performance data.

Note: if only FW domain is tested, steps 8-10 are skipped. If only time domain is tested, step 7 is skipped.

7.6 Acceptance Criteria

Acceptance criteria are determined using the definitions provided in the grid code. The following sections contain different acceptance criteria.

7.6.1 Default Requirements

The maximum difference between the programmed expected output and response is less or equal than the manufacturer's stated power accuracy (MSA_P) at any frequency defined by the region $f_{test} \pm (MSA_{Hz}$ plus the DAS frequency accuracy). The maximum difference between the programmed response time and actual response is less or equal than the manufacturer's stated time accuracy (MSA_t) plus the DAS time accuracy.

7.6.2 Italian Technical Rules

The EUT active power error is less than $\pm 2.5\%$ of the EUT nameplate apparent power.

7.6.3 UL 1741 SA Draft Criteria

For each frequency step, the EUT should remain within the stated accuracy of the $P(f)$ characteristic except when the frequency is changing. The EUT shall obtain the $P(f)$ characteristic within its stated accuracy within the stated settling time. For rising frequency (and for falling frequency with hysteresis disabled), the EUT shall be considered in compliance if, for each line cycle after the manufacturer's stated settling time t_s has passed following a frequency change (see Figure 12) the measured (f, P) data point falls within the boundaries shown in Figure 13 and Figure 14 below.




Figure 12. Frequency vs. time during a portion of the frequency-Watt test.




Figure 13. Frequency-Watt test criteria.

$a_2 = MSA_P$, $b = MSA_{Hz}$.




Figure 14. Frequency-Watt test criteria during return to nominal power with hysteresis enabled.

T_a is the time the frequency reaches F_{stop} . $T_{start} = t_a + t_{return}$.
 $a_2 = MSA_P$. $b_2 = MSA_t$. P_b is the nominal power for the test.

8 Var-Priority Volt-var "Q(V)" Test (VV12)

In order to maintain a stable grid voltage, it is desired that inverters be able to source or sink reactive power. One way to achieve this is to have the inverter source or sink reactive power in response to fluctuations in grid voltage. This test verifies that the EUTs volt-var mode implements the reactive power response to fluctuations in grid voltage according to a stepwise Q(V) curve. The var-priority function is defined in IEC 61850-90-7 as VV12.

8.1 Function Definition

This function defines how a BESS will provide reactive power support to the grid during a voltage deviation. This test procedure evaluates the functionality required in:

- CEI 0-21
- CEI 0-16
- IEC 61850-90-7
- VDE-AR-N 4105 Germany/FGW - TR3 Rev23 (optional test)
- CLC/TS 50549
- UL 1741 SA
- Austria ÖVE/ÖNORM EN50438 (optional - in accordance with DSO).

Table 29. Review of Grid Codes for the Volt-var Function

Country/ Grid Code	Data Requirements	Specified Curve	Default Values
Italy/CEI 0-21: 2014-12 (LV) and Italy/CEI 0-16: 2014-12(MV)	P, Q, V_{ac} measured (1 s average), Q awaited, Q error	V_{1i} = under voltage at the left edge of the deadband V_{2i} = under voltage at max capacitive reactive power V_{1s} = over voltage at the right edge of the deadband V_{2s} = over voltage at max inductive reactive power Q_{1i} =reactive power at V_{1i} Q_{2i} =reactive power at V_{2i} Q_{1s} =reactive power at V_{1s} Q_{2s} =reactive power at V_{2s} $Q_{max,cap}$ and $Q_{max,ind}$ from capability curve	$V_{1i} = 0.92 V_n, Q_{1i} = 0$ $V_{2i} = 0.9 V_n, Q_{2i} = Q_{max,cap}$ $V_{1s} = 1.08 V_n, Q_{1s} = 0$ $V_{2s} = 1.1 V_n, Q_{2s} = Q_{max,ind}$
US (California)/ UL 1741 SA: 2015	AC and DC current and voltage. The minimum measurement accuracy shall be 1% or less of rated EUT nominal output voltage and 1% or less of rated EUT output current.	Q_1 = maximum capacitive reactive power setting Q_2 = reactive power setting at the left edge of the deadband Q_3 = reactive power setting at the right edge of the deadband Q_4 = maximum inductive reactive power setting V_1 = voltage at Q_1 V_2 = voltage at Q_2 V_3 = voltage at Q_3 V_4 = voltage at Q_4	$V_1 = V_2 - Q_1/KVAR_{max}$, $Q_1 = Q_{max,cap}$ $V_2 = V_n - Deadband_{min}/2, Q_2 = 0$ $V_3 = V_n + Deadband_{min}/2, Q_3 = 0$ $V_4 = Q_4/KVAR_{max} + V_3, Q_4 = Q_{max,ind}$
Germany/ FGW - TR3 Rev23 (optional test)	Displacement factor, P, Q, and V using a 0.2s (min) sliding average. The settling time shall be determined on the basis of $\pm 5\%$ rated active power.	Additional tests are carried out for PGUs with reactive power control with Q(U) characteristic curve. The voltage steps start at the lowest voltage to the highest voltage and vice versa.	none
Austria ÖVE/ÖNORM EN50438 (optional - in accordance with DSO, e.g. function used by local DSO --	Displacement factor, P, Q, and V using a 0.2s (min) sliding average. The settling time shall be determined on the basis of $\pm 5\%$	V_{1i} = under voltage at the left edge of the deadband V_{2i} = under voltage at max capacitive reactive power V_{1s} = over voltage at the right edge of the deadband V_{2s} = over voltage at max inductive reactive power	e.g. for DSO Vorarlberg Netz: $V_{1i} = 1.02 V_n, Q_{1i} = 0$ $V_{2i} = 0.99 V_n, Q_{2i} = Q_{max,cap}$ $V_{1s} = 1.05 V_n, Q_{1s} = 0$

**Vorarlberg
Netz)**

rated active
power.

Q_{1i} =reactive power at V_{1i}
 Q_{2i} =reactive power at V_{2i}
 Q_{1s} =reactive power at V_{1s}
 Q_{2s} =reactive power at V_{2s}
 $Q_{max, cap}$ and $Q_{max, ind}$ from capability
curve

$V_{2s} = 1.08 V_n$, $Q_{2s} =$
 $Q_{max, ind}$

Additionally a dynamic of the
response must be configurable.
(Dynamic according first order filter
with adjustable time constant
between 3 s and 60 s. Duration
until 95 % of the new set point
after a voltage deviation is 3-times
of the time constant.

**International
/ IEC 61850-
90-7⁷⁶**

Monitor and
record electrical
output of EUT.
• Voltage
• Active power
• Reactive power

Pointwise definition with (V_1, Q_1)
through (V_x, Q_x) points.
• Q_x = Desired reactive power
setting at V_x
• V_x = Voltage setting at Q_x .

No default. Example
settings are:
 $V_1 = 0.97 V_n$, $Q_1 =$
 $50\% Q_{MAXover}$
 $V_2 = 0.99 V_n$, $Q_2 = 0$
 $V_3 = 1.01 V_n$, $Q_3 = 0$
 $V_4 = 1.03 V_n$,
 $Q_4 = 50\% Q_{MAXunder}$

8.2 Parameters

Before starting the VV test, the following parameters will be determined by the manufacturer and test engineer for use in the procedure.

⁷⁶ Evaluated with the Sandia Interoperability Test Protocols.

Table 30. VV Test Parameters

Parameter	Notes
VV Curve⁷⁷	Arrays of (V_x, Q_x) pairs where x is the point number
VV Curve h	Arrays of $(V_x, Q_x)_h$ pairs where x is the point number and h indicates a hysteresis curve.
t_w	Time window is an optional parameter in which the function is enabled after a delay. The delay can be random or fixed. If the time delay is zero, the command will execute immediately.
r_R	Requested ramp rate ($\%Q_{rated}/s$) is an optional parameter defining the slope the EUT must move from the current set point to the new set point. The corresponding Requested ramp time $t_R=1/r_R$ express the time for full execution.
t_{RD}	Recovery delay is an optional parameter expressing the waiting time after the grid voltage reaches the hysteresis curve.
r_{Rec}	Recovery ramp rate ($\%Q_{rated}/s$) is an optional parameter defining how quickly the EUT output returns to normal (default) values after voltage reaches the hysteresis curve. The corresponding recovery ramp time $t_{Rec}=1/r_{Rec}$ expresses the time for full execution.
t_{out}	Timeout period is an optional parameter that defines the time after which the EUT will reset the volt-var function and set the reactive power to a default value. The default timeout period is indefinite (timeout period = 0 – Not Enable).

Table 31. Manufacturer Parameters

Parameter	Notes
W_{MAXch}	Maximum charge active power rating (W) – negative value
W_{MAXdch}	Maximum discharge active power rating (W) – positive value ⁷⁸
Q_{MAXunder}	Maximum Underexcited Reactive Power ⁷⁹
Q_{MAXover}	Maximum Overexcited Reactive Power
[V_{min}, V_{max}]	AC voltage range with function enabled (V)
V_{nom}	AC nominal voltage (V)
K_{VARmax}	Maximum Slope (var/V)
[Deadband_{min}, Deadband_{max}]	Deadband Range (V)
MSA_t⁸⁰	Accuracy of time (s)

⁷⁷ While it is possible for VV function reference parameters to be specified in a variety of grid code or EUT, for this protocol, the VV curves will be defined with (V, Q) points.

⁷⁸ Grid-centric nomenclature from IEC 61850-90-7 is adopted here.

⁷⁹ This protocol follows the IEEE Std-1459-2000 reactive power sign convention, in which an overexcited power factor is positive and an underexcited power factor is negative.

MSA_{VAR}	Reactive Power Accuracy (% or var)
MSA_{Vac}	AC voltage accuracy (V)
SOC_{OpMAX}	Maximum operative state of charge at maximum reactive power (%) ⁸¹
SOC_{OpMIN}	Minimum operative state of charge at maximum reactive power (%)
[t_{w_min}, t_{w_max}]	Adjustment range of time window (s).
[r_{R_min}, r_{R_max}]	Adjustment range of the ramp rate (var/s)
[t_{RD_min}, t_{RD_max}]	Adjustment range of recovery delay time (s). t _{RD_min} will be 0 for most EUTs.
[r_{Rec_min}, r_{Rec_max}]	Adjustment range of the rate of return to normal operation (%Q _{rated} /s)
[t_{out_min}, t_{out_max}]	Adjustment range of timeout period (s)

VV12 allows more than one voltage-var curve to be specified. Furthermore, voltage-var settings may be different in under or over voltage conditions. In order to define VV12 inverter response, set-up parameters must be configured in the EUT.




Figure 15. Example VV12 points definition.

⁸⁰ The manufacturer's stated accuracy is necessary for some of the pass/fail criteria in certain grid codes, e.g., UL 1741 SA. It is also used for general acceptance criteria.

⁸¹ This information can also be provided in tabular or function formats with active power limits vs SOC level.

8.3 Function Capability Table (FCT)

The FCT should be filled out based on the capabilities of the EUT. Two different tests are undertaken: VV Domain Test and Time Domain Test. The possible VV modes to be tested depend on:

- Hysteresis
- Reactive Power Offset:
 - Overexcited
 - Underexcited
- Timing parameters:
 - ramp time, t_R
 - time window, t_w
 - timeout, t_{out}

Table 32. VV12 Function Capability Table for VV12 Domain Test

Test Type	Reactive Power Offset	Hysteresis	Timing	Tests
VV domain	No	No	Default	Test #1 in Table 35
	No	Yes	Default	Test #2 in Table 35
	Overexcited	No	Default	Test #3 in Table 35
	Overexcited	Yes	Default	Test #4 in Table 35
	Underexcited	No	Default	Test #5 in Table 35
	Underexcited	Yes	Default	Test #6 in Table 35

Table 33. Function Capability Table for VV12 Timing test

Test Type	Hysteresis	Time window & Ramp time	Timeout	Timing test number
Time domain	No	No	No	Test #t1 default in Table 36
	No	Yes	No	Test #t2 and Test #t3 in Table 36
	Yes	No	No	Test #t4 and Test #t5 in Table 36
	Yes	Yes	No	Test #t6 and Test #t7 in Table 36
	No	No	Yes	Test #t8 and Test #t9 in Table 36

8.4 VV12 Function Test Definition

8.4.1 VV12 Domain Test

VV domain test verifies the EUT operation according to the required test condition as defined in FCT (Table 32). Test will be performed setting up the EUT on the basis of the VV test curves as in Table 34. All the timing parameters will be set to 0. Each test is executed at five different starting active power levels ranging from W_{MAXch} and W_{MAXdch} , with reactive power set to 0. For each power level, test is carried out at different voltage values adjusted, with a grid simulator, between $V_{min} + \Delta V$ ⁸² and $V_{max} - \Delta V$ in order to avoid the EUT disconnection at the voltage limits. Along each of the VV trajectory lines defined by VV test curves a minimum of 3 points⁸³ is required. Each point must be held for the greater of 5 seconds and $2 \cdot t_s$.

⁸² ΔV is calculated as the composed accuracy of the EUT voltage measurement accuracy and the grid simulator voltage setup accuracy. A typical value defined in codes/rules could be about +/-2% of V_{nom} .

⁸³ This can be adjusted if National Codes/Rules require a different number of points. A minimum of three AC voltage settings will be used, but additional test points maybe necessary. The voltage between points should be large enough to resolve the var accuracy of the EUT for the function.

Table 34. VV12 Test Curves

		Format: $Q(V) = [(V_x, Q_x)]$
Generic VV12 and Hysteresis Test Curves	VV12 Test Curve 1	$[(V_{max}, Q_{MAXunder}); (V_{nom} - Deadband_{min}/2, 0); (V_{nom} + Deadband_{min}/2, 0); (V_{min}, Q_{MAXover})]$
	VV12 Test Curve 2	$[(V_{max}, Q_{MAXunder}); (V_{nom} - Deadband_{min}/2, Q_{offset}); (V_{nom} + Deadband_{min}/2, Q_{offset}); (V_{min}, Q_{MAXover})]$
	Hysteresis Test Curve 1	$[(V_{max}, Q_{MAXunder}); (V_{max} - Deadband_{min}/4, Q_{MAXunder}); (V_{nom} + Deadband_{min}/4, 0); (V_{nom} - Deadband_{min}/4, 0); (V_{min} + Deadband_{min}/4, Q_{MAXover}); (V_{min}, Q_{MAXover})]$
	Hysteresis Test Curve 2	$[(V_{max}, Q_{MAXunder}); (V_{max} - Deadband_{min}/4, Q_{MAXunder}); (V_{nom} + Deadband_{min}/4, Q_{offset}); (V_{nom} - Deadband_{min}/4, Q_{offset}); (V_{min} + Deadband_{min}/4, Q_{MAXover}); (V_{min}, Q_{MAXover})]$
Grid Code Specific VV12 and Hysteresis Test Curves	CEC Rule 21 ⁸⁴ Curve "Most Aggressive"	$[(V_2 - Q_1/K_{VARmax}, Q_{MAXunder}); (V_{nom} - Deadband_{min}/2, 0); (V_{nom} + Deadband_{min}/2, 0); (V_3 + Q_4/K_{VAR}, Q_{MAXover})]$
	CEC Rule 21 Curve "Average"	$[(V_2 - Q_1/K_{VARavg}, 0.5Q_{MAXunder}); (V_{nom} - Deadband_{avg}/2, 0); (V_{nom} + Deadband_{avg}/2, 0); (V_3 + Q_4/K_{VARavg}, 0.5Q_{MAXover})]$
	CEC Rule 21 Curve "Least Aggressive"	$[(V_2 - Q_1/K_{VARmin}, 0.25Q_{MAXunder}); (V_{nom} - Deadband_{max}/2, 0); (V_{nom} + Deadband_{max}/2, 0); (V_3 + Q_4/K_{VARmin}, 0.25Q_{MAXover})]$
	CEI 0-16/21 VV12 Test Curve	$[(1.1V_{nom}, Q_{MAXunder}); (1.08V_{nom}, 0); (0.92V_{nom}, 0); (0.9V_{nom}, Q_{MAXover})]$

⁸⁴ The following parameters will be calculated:

- $V_{dev} = \min(V_{nom} - V_{min}, V_{max} - V_{nom})$, the minimum voltage deviation from V_{nom} which causes the EUT to stop volt-var operation
- $K_{VARmin} = (Q_{MAXunder}/4)/(V_{dev} - Deadband_{max}/2)$ or as specified by the Source Requirements Document
- $K_{VARavg} = (K_{VARmax} + K_{VARmin})/2$
- $Deadband_{avg} = (Deadband_{max} + Deadband_{min})/2$.

Table 35. VV12 Test Matrix

	Test #	Curves		Q _{offset}
		VV12 Curve	Hysteresis Curve	
Generic VV12 and Hysteresis Test Curves	1	VV12 Test Curve 1		
	2	VV12 Test Curve 1	Hysteresis Test Curve 1	
	3	VV12 Test Curve 2		0.05Q _{MAXover}
	4	VV12 Test Curve 2	Hysteresis Test Curve 2	0.05Q _{MAXover}
	5	VV12 Test Curve 2		0.05Q _{MAXunder}
	6	VV12 Test Curve 2	Hysteresis Test Curve 2	0.05Q _{MAXunder}
Grid Code Specific VV12 and Hysteresis Test Curves	7	UL 1741 Curve "Most Aggressive"		
	8	UL 1741 Curve "Average"		
	9	UL 1741 Curve "Least Aggressive"		
	10	CEI 0-16/21 VV12 Test Curve		

*Note: These tests should be repeated with active power set from 0 to 100%·W_{MAXch} in increments of 20%·W_{MAXch} and 0 to 100%·W_{MAXdch} in increments of 20%·W_{MAXdch}.

8.4.2 VV12 Timing Test

The volt-var timing tests consist of two steps from the nominal voltage to $V_{min} + \Delta V$ and back to nominal voltage then from the nominal frequency to $V_{max} - \Delta V$ and back to nominal voltage. Each voltage step is held for a minimum test duration (timing interval) equal to 2 times ($t_R + t_{window} + t_{out}$) according to Table 36 plus twice the EUT settling time (t_s).

Table 36. VV12 Timing Test Matrix

	Test #	Ramp time, t_R (s)	Recovery Delay time, t_{RD} (s)	Recovery ramp time, t_{Rec} (s)	Time window, t_W (s)	Timeout, t_{out} (s)
Generic VV12 and Hysteresis Test Curves	t1 DEFAULT	0	0	0	0	0
	t2	$t_{R_max}/2$	0	0	$t_{W_max}/2$	0
	t3	t_{R_max}	0	0	t_{W_max}	0
	t4	0	$t_{RD_max}/2$	$t_{Rec_max}/2$	0	0
	t5	0	t_{RD_max}	t_{Rec_max}	0	0
	t6	$t_{R_max}/2$	$t_{RD_max}/2$	$t_{Rec_max}/2$	$t_{W_max}/2$	0
	t7	t_{R_max}	t_{RD_max}	t_{Rec_max}	t_{W_max}	0
	t8	0	0	0	0	$t_{out_max}/2$
	t9	0	0	0	0	t_{out_max}
Grid Code Specific VV12 and Hysteresis Test Curves	1 (CLC/TS 50549)	9	0	0	0	0
	2 (CLC/TS 50549)	180	0	0	0	0

8.5 VV12 Function test Sequence

The VV12 test shall be carried out as follows:

Step 1: Prepare the EUT according to the following:

- Configure EUT and energy storage element according to Section 2.1.
- Connect to Utility Simulator with operation within nominal voltage range for a minimum of 5 minutes.
- Verify EUT is powered on to a level required to receive the command.
- Verify energy storage state of charge (SOC) will not interfere with VV12 tests. If the SOC is near SOC_{opMAX} or SOC_{opMIN} , charge or discharge the BESS system until close to: $(SOC_{opMAX} + SOC_{opMIN})/2$.
- Establish communication to EUT with Utility Management System (UMS).
- Record EUT output (e.g., voltage, current, power) with data acquisition system according to Section 2.2.
- Set Active and Reactive Power to zero.

Step 2: Request status from EUT and record the EUT parameters.

Step 3: Send VV12 (V, Q) pairs according to required test as in Table 34.

Step 4: Confirm VV12 parameters are updated in the EUT.

Step 5: Send default timing parameters to EUT according to Table 36.

Step 6: Set the EUT power to required power level (starting value 0).

Step 7: Adjust the grid voltage to the required grid voltage points: 5 points per line including also line to Hzmin + Δf and Hzmax- Δf points. The tests will follow this sequence: V_{nom} to $V_{max}-\Delta V$ to V_{nom} to $V_{min} +\Delta V$ and then back to V_{nom} .

Step 8: Set the timing parameters according to Table 36.

Step 9: Step the grid frequency to $V_{min} +\Delta V$ and $V_{max}-\Delta V$ according to Section 8.4.2.

Step 10: Repeat Steps 8-9 with new timing parameters based on the FCT (Timing tests).

Step 11: Repeat Steps 5-10 with the EUT power set to $100\% \cdot W_{MAXch}$ to $20\% \cdot W_{MAXch}$ in steps of $20\% \cdot W_{MAXch}$ and $100\% \cdot W_{MAXdch}$ to $20\% \cdot W_{MAXdch}$ in steps of $20\% \cdot W_{MAXdch}$

Step 12: Repeat Steps 3-11 with VV12 new pairs based on the FCT (VV12 domain tests).

Step 13: Analyze performance data.

8.6 Acceptance Criteria

Acceptance criteria are determined using the definitions provided in the grid code.

8.6.1 Default Criteria

The maximum difference between the measured reactive power and the reactive power settings must be less than MSA_{VAR} at any voltage defined by the region $V_{test} \pm (MSA_{Vac}$ plus the DAQ V_{ac} accuracy). The maximum difference between the measured time response and the time response settings must be less than MSA_t plus the DAQ time accuracy.

8.6.2 Italian Technical Rules

The maximum difference between the measured reactive power and the reactive power output must be less than $\pm 5\%$ of S_n (nominal apparent power).

8.6.3 CLC/TS 50549

The maximum difference between the measured reactive power and the set reactive power is less than $\Delta Q < \pm 2\%$ of the EUT nameplate apparent power in the range 10% - 100% of nameplate apparent power.